Cyfoeth Naturiol Cymru
Natural Resources Wales

Ein cyf/Our ref: CAS-262731-L8N3
Eich cyf/Your ref: P/2024/1329

Wrexham County Borough Council
The Guildhall
Wrexham
LL11 1AY

Date: 03 September 2024

Dear Sir/Madam,

**PROPOSAL: Change of use of building to beauty salon**

**LOCATION: The Coach House, Llay Road, Cefn y Bedd (Salon)**

Thank you for consulting Cyfoeth Naturiol Cymru (CNC)/Natural Resources Wales (NRW) about the above, which we received on 16 August 2024.

**We have concerns with the application as submitted because inadequate information has been provided in support of the proposal. To overcome these concerns, you should seek further information from the applicant regarding foul drainage. If this information is not provided, we would object to this planning application. Further details are provided below.**

**Foul Drainage and Protected Sites**

We note the application site is within the catchment of the River Dee and Bala Lake Special Area of Conservation (SAC). In line with our *Advice to Planning Authorities for Planning Applications Affecting Nutrient Sensitive River Special Areas of Conservation* (28 June 2024), under the Habitats Regulations, Planning Authorities must consider the impact of proposed developments on water quality within SAC river catchments. We therefore advise you to consider whether the proposals, as submitted, would increase the volume of foul discharge from the site in planning terms.

We note from the information submitted that a new septic tank is to be installed to provide foul drainage for the development. Should you consider the development to constitute an increase in foul discharge, we refer you to our Advice and advise you to seek further information from the applicant as identified in the section titled '*What does this mean for development proposals involving private sewage treatment systems'* of that Advice.

Ultimately, the suitability of foul drainage arrangements for the proposed development is a matter for your Authority to determine. We therefore advise you to take the above into account in your determination of whether the development is likely to have a significant effect

on the SAC. Should you determine that an Appropriate Assessment is required, the Applicant will then need to submit whatever evidence they deem appropriate (seeking advice from consultants as may be necessary) to demonstrate no adverse effect on site integrity.

**Protected Species**

No ecological information has been submitted in support of this application. We recommend you seek the advice of your Authority's ecologist about the requirement for further information to be submitted in support of the application, and to scope the need for bespoke surveys, where required.

**Other Matters**

Our comments above only relate specifically to matters included on our checklist, *Development Planning Advisory Service: Consultation Topics* (September 2018), which is published on our website. We have not considered potential effects on other matters and do not rule out the potential for the proposed development to affect other interests.

We advise the applicant that, in addition to planning permission, it is their responsibility to ensure they secure all other permits/consents/licences relevant to their development. Please refer to our website for further details.

If you have any queries on the above, please do not hesitate to contact us.

Yours faithfully,

**Tristan Williams**
Cynghorydd - Cynllunio Datblygu/Advisor - Development Planning
Cyfoeth Naturiol Cymru/Natural Resources Wales

E-bost/E-mail: northplanning@cyfoethnaturiolcymru.gov.uk

Croesewir gohebiaeth yn Gymraeg a byddwn yn ymateb yn Gymraeg, heb i hynny arwain at oedi./Correspondence in Welsh is welcomed, and we will respond in Welsh without it leading to a delay.