

0 1m 2m 3m 4m 5m

0 100mm

SCALE 1:50

GENERAL NOTES:

- DO NOT SCALE FROM THIS DRAWING. ALL DIMENSIONS ARE NOMINAL & MUST BE CHECKED ON SITE
- TO BE READ IN CONJUNCTION WITH ARCHITECTS & ENGINEERS DRAWINGS, SPECIFICATIONS & SCHEDULES
- ANY DISCREPANCIES SHOULD BE BROUGHT TO THE ATTENTION OF THE CONSULTANT, **IF IN DOUBT ASK**
- FOR DIMENSIONED SETTING OUT & ELEVATION DETAILS REFER TO ARCHITECTS DRAWINGS
- THESE DRAWINGS ARE COPYRIGHT OF WATERSTONE DESIGN LTD. PLEASE OBTAIN PERMISSION BEFORE COPYING. THESE DRAWINGS MUST NOT BE MODIFIED OTHER THAN BY WATERSTONE DESIGN LTD

GENERAL MECHANICAL NOTES:

- DRAWING TO BE READ IN CONJUNCTION WITH EMPLOYERS REQUIREMENTS & CONTRACT DOCUMENTS
- ALL EQUIPMENT TO BE INSTALLED AS PER MANUFACTURERS INSTRUCTIONS
- LOCATION OF INCOMING SERVICES TO BE CONFIRMED BY LOCAL STATUTORY AUTHORITY
- PIPEWORK ROUTES ABOVE CEILING ARE INDICATIVE. EXACT PENETRATION POINTS THROUGH ENGINEERED BEAMS TO BE CONFIRMED BY STRUCTURAL ENGINEER
- ALL TAP FITTINGS & CONTROLS TO BE MOUNTED WITHIN GUIDELINE HEIGHTS AS SPECIFIED IN THE BUILDING REGULATIONS APPROVED DOCUMENT PART M & LIFETIME HOMES (HEIGHT 450 - 1200mm & AT LEAST 300mm FROM INTERNAL CORNERS)

LEGEND:

- SUPPLY DUCTWORK (NEW)
- EXTRACT DUCTWORK (NEW)
- SUPPLY DUCTWORK (EXISTING)
- EXTRACT DUCTWORK (EXISTING)
- DUCTWORK FOR FCU'S (EXISTING & TO REMAIN)

ABBREVIATIONS

CTA	CROSS TALK ATTENUATOR
VCD	VOLUME CONTROL DAMPER
SD	SMOKE/FIRE DAMPER

SMOKE AND FIRE DAMPER REQUIREMENTS TO BE CONFIRMED BY FIRE STRATEGY. NUMBER OF DAMPERS MAY NEED TO BE REVIEWED.

Rev	Description	Date	Drawn - Checked - Appr
P4	UPDATED GRILLE REFERENCE	09.05.24	AH - BR - BR
P3	UPDATED UNIT SELECTION	30.04.24	AH - BR - BR
P2	UPDATED AS PER CLIENT COMMENTS	11.04.24	AH - BR - BR
P1	PRELIMINARY ISSUE	04.04.24	AH - BR - BR

Waterstone Design
Building Services & Environmental Consultants

Ingenium House,
Sir Thomas Longley Road,
Medway City Estate,
Rochester, Kent, ME2 4DU

Tel: 01634 727255

mail@waterstonedesign.co.uk
www.waterstonedesign.co.uk

Client: fit out

Project: LLOYDS, WREXHAM

Title: 1ST FLOOR VENTILATION LAYOUT

First Drawn By:	Date Created:	Scale:	First Designed by:
AH	APR/24	1:50@A1	BR

WSD Project No:	Drawing No:	Rev:
D2654	D2654-WSD-ZZ-01-DR-ME-57002	P4