wrexham
COUNTY BOROUGH COUNCIL
CYNGOR BWRDEISTREF SIROL
wrecsam

MEMORANDUM

From: **Ian Jones**
Head of Service Public Protection

To: **Matthew Phillips**
Head of Service Planning Development

Our Ref:

Your Ref: P/2024/1323

Date: 02-10-2024

Town and Country Planning Act 1990

Town and Country Planning (General Development Procedure) Order 1996

Re: P/2024/1323, THE RACECOURSE, MOLD ROAD, WREXHAM, LL11 2AH

ESTYNIAD I'R STAND DROS DRO PRESENNOL I GYNYDDU'R CAPASITI I 3,020 / EXTENSION TO CURRENT TEMPORARY STAND TO INCREASE CAPACITY TO 3,020

INF22 – MINOR DEMOLITION CONSTRUCTION NOISE

All works in relation to the implementation of this permission, including deliveries to and /or leaving the site, should be undertaken only between the hours of 07.30 to 18.00 Monday to Friday, 08.00 to 14.00 on a Saturday, and at no time on a Sunday or a Bank Holiday. Outside these times, any works which are audible beyond the site boundary have the potential to cause unreasonable disturbance to neighbouring premises.

The applicant is advised that the Council has the option to control construction noise by serving a Control of Pollution Act 1974, Section 60 Notice where deemed necessary, and failure to comply with such a Notice can result in prosecution.

The applicant is further advised that any complaints received relating to noise of any type from the development may also be investigated using the Council's Standardised Procedure for Dealing with Noise Nuisance Complaints. This is done under the Statutory Nuisance provisions provided within the Environmental Protection Act 1990, and legal action may be taken where appropriate.

The applicant must adhere to the times given above wherever possible. If, however, there are urgent or unavoidable circumstances requiring work outside of the specified times, permission to proceed may be sought by contacting Environmental Health & Housing Standards at healthandhousing@wrexham.gov.uk or 01978 292040. Please use the same contact details for any other enquiries regarding construction / demolition site noise.

RPT 2 - REPORT REQUIRED

Due to the presence of residential receptors near to the proposal this section will require a noise report so as to make appropriate recommendations, this report should be provided prior to determination and address the noise impact from both the existing temporary stand (as per Technical note - WAFC Temporary Spectator Stand, dated 18-12-2023 Project No 1620012485 provided for P/2023/0907) and this proposed extension. The noise survey shall determine noise levels, having regard to Planning Policy Wales (PPW) Guidance, Technical Advice Note (TAN) 11 – Noise. The report of the noise survey findings shall include:

a)Noise levels arising in the vicinity of the proposed development site and the impact upon the existing accommodation, and

b) A detailed scheme of noise insulation and / or attenuation measures so designed to safeguard the amenity of the existing accommodation.

……

Head of Service Public Protection