Ellie Jones

From: North Planning <NorthPlanning@cyfoethnaturiolcymru.gov.uk>
Sent: 28 February 2025 10:00
To: planning_admin
Subject: P/2025/0161 - CARREG Y FFRANC, BANGOR ROAD, OVERTON, WREXHAM, LL13 0HL (Minor) - Insufficient Information NRW:01952641

Dear Planning,
Thank you for consulting Natural Resources Wales on the above application.

We have undertaken an initial review of the application and note that the following information has either not been submitted or is not available to view on your Authority's website.

- Full details on how the silage effluent is to be collected and stored.
- Capacity and construction standards of the silage effluent tank and any channels.
- Confirmation it will be designed and built to the construction and capacity requirements detailed in CoAPR.

In order for us to provide you with comments on the proposed development we require the submission of the above information. We look forward to being formally reconsulted when this information is available.
Kind Regards
Sara Thomas
Tîm Cynllunio Datblygu / Development Planning Team
Cyfoeth Naturiol Cymru / Natural Resources Wales
Ffôn / Tel: +443000653181
www.cyfoethnaturiolcymru.gov.uk / www.naturalresourceswales.gov.uk
Yn falch o arwain y ffordd at ddyfodol gwell i Gymru trwy reoli'r amgylchedd ac adnoddau naturiol yn gynaliadwy / Proud to be leading the way to a better future for Wales by managing the environment and natural resources sustainably.
Croesewir gohebiaeth yn Gymraeg a byddwn yn ymateb yn Gymraeg, heb i hynny arwain at oedi / Correspondence in Welsh is welcomed, and we will respond in Welsh without it leading to a delay.