wrexham
COUNTY BOROUGH COUNCIL
CYNGOR BWRDEISTREF SIROL
wrecsam

MEMORANDUM

From: **Ian Jones**
Head of Service Public Protection

To: **Matthew Phillips**
Head of Service Planning Development

Our Ref:

Your Ref: P/2025/0177

Date: 12-03-2025

Town and Country Planning Act 1990

Town and Country Planning (General Development Procedure) Order 1996

Re: P/2025/0177, UNITS 4-6, WYNNSTAY INDUSTRIAL ESTATE, RUABON, LL14 6EN

GOSOD 2 UNED PWMP GWRES FFYNHONNELL AER ALLANOL / INSTALLATION OF 2 NO EXTERNAL AIR SOURCE HEAT PUMP UNITS

EN08 - NOISE SURVEY

No part of the development shall commence until a noise survey has been carried out, and a detailed report of the survey findings has been submitted to, and approved in writing by, the Local Planning Authority. The noise survey shall determine noise levels for both Day (07:00 – 23:00 hours) and Night (23:00 – 07:00 hours), having regard to Planning Policy Wales (PPW) Guidance, Technical Advice Note (TAN) 11 – Noise. The report of the noise survey findings shall include:

a)Noise levels arising from day / night time activities in the vicinity of the proposed development site and the impact upon the existing or proposed accommodation, and

b) A detailed scheme of noise insulation and / or attenuation measures so designed to safeguard the amenity of the existing or occupants of the proposed accommodation hereby approved.

The measures as are approved shall be fully implemented prior to the first occupation / use of the development.

EN07 - NOISE GENERATION - NOISE LEVEL CONDITION

The rating level of any noise generated by reason of this development shall not exceed the pre-existing background level at any time. The noise levels shall be determined at nearby noise sensitive premises, and measurements and assessment shall be made in accordance with BS4142:2014 Methods for Rating and Assessing Industrial and Commercial Sound.

……

Head of Service Public Protection