

Maes Y Ffynnon,
Penrhosgarnedd,
Bangor,
Gwynedd
LL572DW

Wrexham County Borough Council,
The Guildhall,
Wrexham,
LL11 1AY

ebost/email:
northplanning@cyfoethnaturiolcymru.gov.uk

21/02/2025

Annwyl Syr/Madam / Dear Sir/Madam,

BWRIAD / PROPOSAL: HYBRID APPLICATION - (A) FULL PERMISSION ERECT 31 UNITS FOR B1/B2/B8 USE, (B) OUTLINE PERMISSION FOR UP TO 13 INDUSTRIAL (B1/B2/B8 USE) WITH ASSOCIATED ACCESS, LANDSCAPING AND ASSOCIATED WORKS.

LLEOLIAD / LOCATION: THE BRIDGEWAY CENTRE, BRIDGE ROAD, WREXHAM INDUSTRIAL ESTATE, WREXHAM, LL13 9QS

Thank you for consulting Cyfoeth Naturiol Cymru / Natural Resources Wales about the above, which we received on 11/02/2025.

We continue to have concerns with the application as submitted because inadequate information has been provided in support of the proposal. To overcome these concerns, further consideration is required regarding foul drainage. Further details are provided below.

We also advise that based on the information submitted to date, conditions regarding Land Contamination and Protected Species should be attached to any planning permission granted and the documents identified below should be included in the approved plans and documents condition on the decision notice. Without the inclusion of these conditions and documents, we would object to this planning application.

Conditions: 1-2 Land Contamination

Documents:

Foley, N (2024) Bat Presence / Absence Survey: Bridgeway Centre, Bridge Road, Wrexham, LL13 9QS. United Environmental Services. (Unpublished Report No UES03012/13)

Clark, E. (2020). Preliminary Ecological Appraisal: Bridgeway Centre, Bridge Road, Wrexham, LL13 9QS. United Environmental Services. (Unpublished Report No UES03012/01)

Protected Sites – Foul Drainage

The proposed development could potentially lead to an increase of phosphorus load from the receiving wastewater treatment works into the River Dee and Bala Lake Special Area of Conservation. The majority of the River Dee catchment in Wales is currently failing to meet water quality targets for phosphorus. The nutrient impacts of new connections need to be considered on a case-by-case basis within the Habitats Regulations Assessment process. Whilst NRW permitting service has completed a Review of Water Company Discharge Permits we are currently undertaking further data analysis for the River Dee following a number of enquiries and questions from stakeholders and several ongoing Appeals. We will be able to provide further advice to your Authority once we have concluded the review.

Land Contamination

The Site for development is located within or near to several controlled waters and conservation features. A drain lies immediately to the north of the Site draining to Redwither Brook, which is approx. 20 m NE of Site and flows into the nearby Afon Clywedog, which flows into the River Dee. The Site is in the River Dee catchment and lies in between two Groundwater Source Protection Zones (SPZs) approximately 200 m north and south of the Site boundaries. Because of the Site's current and past history as outlined in the Phase I Preliminary Risk Assessment (PRA) Report (Sutcliffe, July 2017), and as stated in the Conclusions and Recommendations of the PRA (extract below), we agree that additional work recommended by Sutcliffe is required.

Extract from Sutcliffe, July 2017: Recommendations and Conclusions

Based on the findings of the Phase I PRA review, Sutcliffe Investigations do not consider there to be any identifiable significant environmental issues regarding the site, however without an investigation of the site this cannot be discounted as the site has previously and currently been used for varied industrial purposes, There is limited information of the ground for geotechnical properties and as such we would therefore recommend the following sequential works are undertaken:

- *Commission an Initial UXO Desk Based Assessment. If this confirms a medium to high risk from UXO then a Detailed UXO Desk Based Assessment will be required.*
- *Submission of this Phase I PRA Report for the benefit of validating the outline planning application.*
- *Commission a Phase II Ground Investigation designed to discharge any contaminated land conditions that may be assigned to the site and allow the design of economic foundation solutions.*
- *Commission a Flood Risk Assessment"*

Based on the potential risk to nearby controlled waters (and other potential receptors) we recommend that the Local Authority apply the following Contaminated Land Conditions.

Condition 1: Land affected by contamination - No development shall commence until the components 2 through 4 of a scheme to deal with the risks associated with potential contamination at the site, has been submitted to and approved in writing by the Local Planning Authority. As noted above, component 1 has been submitted.

1. A preliminary risk assessment which has identified:
 - a. all previous uses
 - b. potential contaminants associated with those uses
 - c. a conceptual model of the site indicating sources, pathways and receptors
 - d. potentially unacceptable risks arising from contamination at the site
2. A site investigation scheme, based on (1) to provide information for a detailed assessment of the risk to all receptors that may be affected, including those off site.
3. The results of the site investigation and the detailed risk assessment referred to in (2) and, based on these, an options appraisal and remediation strategy giving full details of the remediation measures required and how they are to be undertaken.
4. A verification plan providing details of the data that will be collected in order to demonstrate that the works set out in the remediation strategy in (3) are complete and identifying any requirements for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action.

The remediation strategy and its relevant components shall be carried out in accordance with the approved details.

Justification: To ensure the risks associated with potential contamination at the site have been fully considered prior to commencement of development as controlled waters downstream of the Site are of high environmental sensitivity; and where necessary remediation measures and long-term monitoring are implemented to prevent unacceptable risks from contamination.

Condition 2: Unsuspected contamination - If, during development, contamination not previously identified is found to be present at the Site then no further development (unless otherwise agreed in writing with the Local Planning Authority) shall be carried out until a remediation strategy detailing how this unsuspected contamination shall be dealt with has been submitted to and approved in writing by the Local Planning Authority. The remediation strategy shall be carried out as approved.

Justification: To ensure the risks associated with previously unsuspected contamination at the site are dealt with through a remediation strategy, to minimise the risk to both future users of the land and neighbouring land, and to ensure that the development can be carried out safely without unacceptable risks.

Protected Species

Great Crested Newts (GCN)

We note that the Preliminary Ecological report submitted in support of the above application (United Environmental Services, August 2020) states that GCN presence is unlikely at the development site. However, we note the reasonable avoidance measures proposed in the event that GCNs are found, and advise that these measures are implemented.

We advise that the report should be included in the 'approved list of plans / documents' condition within the decision notice should consent for the project be granted, to secure the recommendations / avoidance measures discussed within the report with regards to GCN. We advise that the LPA's ecologist should be consulted and discuss whether one way fencing should be included within the GCN Reasonable Avoidance Measures.

We note the submission of a Habitat Management Plan (United Environmental Services Ltd, January 2025. Ref UES03012/21) regarding the area designated for off-site mitigation. We advise that the measures are implemented and that this report should also be included in the 'approved list of plans / documents' condition within the decision notice should consent for the project be granted.

Bats

We note that the bat report submitted in support of the above application (United Environmental Services, August 2024) has identified that bats are present at the application site. From the information submitted, we consider that the proposed development represents a lower risk for bats, as defined in our guidance document '*Natural Resources Wales Approach to Bats and Planning* (2015)'. Bats and their breeding and resting places are protected under the Conservation of Habitats and Species Regulations 2017.

As this is a lower risk case for bats, we consider that the development is not likely to be detrimental to the maintenance of the population of the species concerned at a favourable conservation status in its natural range.

Furthermore, we advise that the proposed development is not likely to harm or disturb the bats or their breeding sites and resting places at this site, provided the avoidance measures described in the bat report are implemented.

The report must be included in the 'approved list of plans / documents' condition within the decision notice should consent for the project be granted.

Please consult us again if any further information shows that this is no longer a lower risk case

Other Matters

Our comments above only relate specifically to matters included on our checklist, *Development Planning Advisory Service: Consultation Topics* (September 2018), which is

published on our [website](#). We have not considered potential effects on other matters and do not rule out the potential for the proposed development to affect other interests.

We advise the applicant that, in addition to planning permission, it is their responsibility to ensure they secure all other permits/consents/licences relevant to their development. Please refer to our [website](#) for further details.

If you have any queries on the above, please do not hesitate to contact us.

Yn gywir / Yours faithfully

Garmon Lewis

Cynghorydd - Cynllunio Datblygu / Advisor - Development Planning

Cyfoeth Naturiol Cymru / Natural Resources Wales