wrexham
COUNTY BOROUGH COUNCIL
CYNGOR BWRDEISTREF SIROL
wrecsam

MEMORANDUM

From: **Ian Jones**
Head of Service Public Protection

To: **Matthew Phillips**
Head of Service Planning Development

Our Ref:

Your Ref: P/2025/0102

Date: 14-05-2025

Town and Country Planning Act 1990

Town and Country Planning (General Development Procedure) Order 1996

Re: P/2025/0102, 13 KING STREET, WREXHAM, LL11 1HF

NEWID DEFNYDD ADEILAD O DDOSBARTH A1 (CIGYDD) I DDOSBARTH A3 (SIOP CLUDFWYD POETH) / CHANGE OF USE OF BUILDING FROM CLASS A1 (BUTCHER) TO CLASS A3 (HOT FOOD TAKEAWAY)

RPT 2 - REPORT REQUIRED

This section is aware that there have been planning applications for residential premises on King Street, As such in order for this section to make an informed recommendation a noise assessment is required for any proposed air handling and / or odour control plant so as to safe guard residential amenity. I recommend this required predetermination:

A noise survey shall be carried out, and a detailed report of the survey findings submitted to, and approved in writing by, the Local Planning Authority. The noise survey shall determine noise levels for both Day (07:00

– 23:00 hours) and Night (23:00 – 07:00 hours), having regard to Planning Policy Wales (PPW) Guidance, Technical Advice Note (TAN) 11 – Noise. The report of the noise survey findings shall include:

a)Noise levels arising from day / night time activities in the vicinity of the proposed development site and the impact upon the existing or proposed accommodation, and

b) A detailed scheme of noise insulation and / or attenuation measures so designed to safeguard the amenity of the existing or occupants of the proposed accommodation hereby approved

EN14 - GREASE TRAPS

Prior to first use of the development a suitable grease trap shall be provided in order to prevent entry into the public sewerage system of matter (cooking fats, oils and grease etc.) likely to interfere with the free flow of the sewer contents, or which would prejudicially affect the treatment and disposal of such contents. The grease trap shall thereafter be permanently retained in a working condition.

EN04 - (ODOUR) KITCHEN EXTRACTION DETAILS REQUIRED

No part of the development shall commence until details of the means of ventilation for the extraction and dispersal of cooking smells, including details of its method of construction, odour control measures, its appearance and finish have been submitted to, and approved in writing by the Local Planning Authority. The system design shall have regard to the guidance set out in EMAQ Report - Control of Odour and Noise from Commercial Kitchen Exhaust Systems (Update to the 2004 report prepared by NETCEN for DEFRA). The approved details shall be fully implemented prior to first use of the development and shall thereafter be permanently retained in an effective condition.

INF30 - FOOD HYGIENE REGULATIONS

You are advised that the premises should comply with the relevant Food Hygiene Legislation, and you are advised to contact Council's Food & Farming Team on foodandfarming@wrexham.gov.uk or 01978 298989 for further advice and information.

INF29 - FOOD PEMISES – FOG ADVICE

Guidance on best management practice for catering outlet for the dispersal of fats, oils, grease and food waste, as issued by Water UK is available by contacting the Council's Environmental Health & Housing Standards Team on healthandhousing@wrexham.gov.uk or 01978 298989 for further advice and information.

……

Head of Service Public Protection