

Ein cyf/Our Ref: CAS-246131-P6G7
Eich cyf/Your Ref: P/2023/0865

Wrexham County Borough Council,
The Guildhall,
Wrexham,
LL11 1AY

Dyddiad/Date: 24 January 2024

Annwyl Syr/Madam / Dear Sir/Madam,

**BWRIAD/PROPOSAL: NEWID DEFNYDD TIR I SAFLE I DEITHWYR GYDA 4 LLAIN /
CHANGE OF USE OF LAND TO TRAVELLER SITE WITH 4 PITCHES**

**LLEOLIAD/LOCATION: LAND AT, STRYT Y BYDDEN, NEW BROUGHTON, WREXHAM,
LL11 6SN**

Thank you for consulting Cyfoeth Naturiol Cymru (CNC) / Natural Resources Wales (NRW) about the above, which we received on 05/01/2024.

We have concerns with the application as submitted because inadequate information has been provided in support of the proposal. To overcome these concerns, you should seek further information from the applicant regarding foul drainage. If this information is not provided, we would object to this planning application. Further details are provided below.

We also advise that based on the information submitted to date, a condition regarding land contamination should be attached to any planning permission granted. Without the inclusion of this condition we would object to this planning application.

Protected Sites and Foul Drainage

We note the application site is within the catchment of the River Dee and Bala Lake Special Area of Conservation (SAC). As you are aware, on the 21st January 2021, we published an evidence package outlining phosphorus levels for all river SACs across Wales. In line with our [Planning Advice](#) (August 2023), under the Habitats Regulations, Planning Authorities must consider the phosphorus impact of proposed developments on water quality within SAC river catchments. We therefore advise you to consider whether the proposals, as submitted, would increase the volume of foul discharge from the site in planning terms.

We note foul water disposal is proposed via the installation of a package treatment plant with discharge to ground, rather than connecting to the mains sewer. However, as you are aware, the site is within a sewered area.

The installation of private sewage treatment facilities within publicly sewered areas is not normally considered environmentally acceptable because of the greater risk of failures leading to pollution of the water environment compared to public sewerage systems.

Section 6.6.21 of Planning Policy Wales states 'Any development discharging domestic sewage should connect to the foul sewer where it is reasonable to do so. Development proposing the use of non-mains drainage schemes will only be considered acceptable where connection to the main sewer is not feasible...'

Government guidance on private sewerage in Welsh Government Circular 008/2018 stresses that the first presumption must be to provide a system of foul drainage discharging into a public sewer. Only where having taken into account the cost and/or practicability it can be shown to the satisfaction of the local planning authority that connection to a public sewer is not feasible, should non-mains foul sewage disposal solutions be considered.

We therefore advise the Applicant to either amend their proposals to ensure that the foul drainage is connected to the mains sewerage system or provide detailed evidence to demonstrate that it is not reasonable to connect.

The Applicant should thoroughly investigate the possibility of connecting to the foul sewer by taking the following steps:

- Approach the sewerage undertaker to reach an agreement for a connection to the foul sewer.
- If the sewerage undertaker refuses connection to the public sewer, request that they adopt the proposed treatment system.
- If the sewerage undertaker refuses both of the above, you must appeal the refusal with Ofwat.

For further details please see [Natural Resources Wales / Private sewage treatment in an area with a public sewer](#)

The Applicant should be aware that should a connection to the mains sewer not be feasible, they will also need to demonstrate that the proposal would not pose an unacceptable risk to the water environment. Welsh Government Circular 008/2018 advises that a full and detailed consideration be given to the environmental criteria listed under paragraph 2.6 of the Circular, in order to justify the use of private sewerage.

As stated above, we expect developers discharging domestic sewage to connect to the public foul sewer where it is reasonable to do so. We will not normally grant a discharge permit for a private sewage treatment system where it is reasonable to connect to the public foul sewer. We also expect discharges of trade effluent to connect to the public foul sewer where it is reasonable to do so and subject to the sewerage undertaker granting a trade effluent consent or entering into a trade effluent agreement.

Furthermore, we refer you to the section in our Planning Advice titled 'What does this mean for development proposals involving connection to public wastewater treatment works'.

Ultimately, the suitability of foul drainage arrangements for the proposed development is a matter for your Authority to determine.

Should your Authority conclude that the proposal is likely to have a significant effect on the River Dee and Bala Lake SAC, please consult us on your Appropriate Assessment under Regulation 63 of the Conservation of Habitats and Species Regulations 2017 (as amended).

Land Contamination

The Design and Access statement (page 5, Brownfield) states that approximately 600mm of surface material has been removed from levelling works, and “*any signs of contamination would have previously been removed*”. There does not appear to be any details of sampling or analysis completed during these works submitted with the application.

We therefore advise the following condition should be attached to any planning permission granted for this proposal.

Condition

If, during development, contamination not previously identified is found to be present at the site then no further development (unless otherwise agreed in writing with the Local Planning Authority) shall be carried out until a remediation strategy detailing how this unsuspected contamination shall be dealt with has been submitted to and approved in writing by the Local Planning Authority. The remediation strategy shall be carried out as approved.

Justification

To ensure the risks associated with previously unsuspected contamination at the site are dealt with through a remediation strategy, to minimise the risk to both future users of the land and neighbouring land, and to ensure that the development can be carried out safely without unacceptable risks.

Protected Species

We note the Initial Habitat and Species Assessment submitted with the application (Camlad Ecology, Land off Stryt y Bydden, New Broughton, Wrexham, Proposed four pitch gypsy/traveller site, Initial habitat and species assessment, November 2023) identifies that there is no evidence of bats or other protected species at the proposed site. We therefore have no comments to make on the application as submitted.

Pollution Prevention

During the construction phase precaution should be taken to prevent contamination of surface water drains and local watercourses. Oils and chemicals should be stored in bunded areas and spill kits should be readily available in case of accidental spillages. For further guidance please refer to Guidance for Pollution Prevention 5: Works and maintenance in or near water, and Pollution Prevention Guidelines 6: Working at construction and demolition sites, which are available on the [NetRegs website](#).

Other Matters

Our comments above only relate specifically to matters included on our checklist, *Development Planning Advisory Service: Consultation Topics* (September 2018), which is published on our [website](#). We have not considered potential effects on other matters and do not *rule out the potential for the proposed development to affect other interests*.

We advise the applicant that, in addition to planning permission, it is their responsibility to ensure they secure all other permits/consents/licences relevant to their development. Please refer to our [website](#) for further details.

If you have any queries on the above, please do not hesitate to contact us.

Yn gywir / Yours faithfully,

Pauline Gallagher Brown

Cynghorydd - Cynllunio Datblygu / Advisor - Development Planning

E-bost/E-mail: northplanning@cyfoethnaturiolcymru.gov.uk

Croesewir gohebiaeth yn Gymraeg a byddwn yn ymateb yn Gymraeg, heb i hynny arwain at oedi. / Correspondence in Welsh is welcomed, and we will respond in Welsh without it leading to a delay.