

06 December 2023

SHD1284-SHD-HLG-MARY-SH-EO-Lighting Schedule-R0

Proposed Unit No.	Easting Coordinates	Northing Coordinates	Unit Location	Unit Description	Service Connection Type	Primary Isolator	Secondary Isolator	Private Cable Network Termination Type
LC01	337566.39	341807.4158	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R0' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Neutral White 9w LED luminaire, complete with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC02	337590.922	341794.5835	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R0' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Neutral White 9w LED luminaire, complete with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC03	337602.847	341812.0832	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R0' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Neutral White 9w LED luminaire, complete with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC04	337620.6457	341832.8637	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R0' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Neutral White 9w LED luminaire, complete with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC05	337635.3388	341838.4626	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R0' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Neutral White 9w LED luminaire, complete with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC06	337660.5164	341828.7045	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R0' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Neutral White 9w LED luminaire, complete with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC07	337676.6025	341805.6693	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R0' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Neutral White 9w LED luminaire, complete with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC08	337684.5812	341781.4115	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R0' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Neutral White 9w LED luminaire, complete with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC09	337662.5755	341793.7012	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R0' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Neutral White 9w LED luminaire, complete with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC10	337623.0982	341868.8976	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R0' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Neutral White 9w LED luminaire, complete with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC11	337631.665	341891.8836	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R0' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Neutral White 9w LED luminaire, complete with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC12	337604.1387	341894.6164	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R0' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Neutral White 9w LED luminaire, complete with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC13	337573.3936	341888.7735	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R0' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Neutral White 9w LED luminaire, complete with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC14	337557.0596	341885.681	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R0' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Neutral White 9w LED luminaire, complete with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC15	337566.5115	341902.8425	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R0' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Neutral White 9w LED luminaire, complete with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A

NOTE: NUMBERS SHOWN ON THE SCHEDULE AND DESIGN DRAWING ARE FOR IDENTIFICATION PURPOSES ONLY - ACTUAL COLUMN NUMBERS TO BE SPECIFIED BY LOCAL AUTHORITY LIGHTING DEPARTMENT OR OVERSEEING ORGANISATION.