

Proposed Unit No.	Easting Coordinates	Northing Coordinates	Unit Location	Unit Description	Service Connection Type	Primary Isolator	Secondary Isolator	Private Cable Network Termination Type
LC01	337566.3900	341807.4158	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R1' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Warm White 2700k 9w LED luminaire, complete with rear shield and with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC02	337590.9220	341794.5835	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R1' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Warm White 2700k 9w LED luminaire, complete with rear shield and with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC03	337602.8470	341812.0832	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R1' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Warm White 2700k 9w LED luminaire, complete with rear shield and with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC04	337620.6457	341832.8637	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R1' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Warm White 2700k 9w LED luminaire, complete with rear shield and with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC05	337641.1342	341846.3173	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R1' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Warm White 2700k 9w LED luminaire, complete with rear shield and with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC06	337651.3299	341826.2860	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R1' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Warm White 2700k 9w LED luminaire, complete with rear shield and with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC07	337676.6025	341805.6693	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R1' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Warm White 2700k 9w LED luminaire, complete with rear shield and with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC08	337681.5428	341789.8757	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R1' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Warm White 2700k 9w LED luminaire, complete with rear shield and with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC09	337657.1634	341794.4078	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R1' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Warm White 2700k 9w LED luminaire, complete with rear shield and with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC10	337623.0982	341868.8976	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R1' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Warm White 2700k 9w LED luminaire, complete with rear shield and with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC11	337620.7018	341893.5926	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R1' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Warm White 2700k 9w LED luminaire, complete with rear shield and with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC12	337586.1221	341887.0983	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R1' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Warm White 2700k 9w LED luminaire, complete with rear shield and with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC13	337557.0596	341885.6810	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R1' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Warm White 2700k 9w LED luminaire, complete with rear shield and with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A
LC14	337566.9405	341906.6141	Refer to 'SHD1284-SHD-HLG-MARY-DR-EO-Lighting Layout-R1' S38 street lighting design drawing	6m galvanised steel lighting column as supplied by CU Phosco as per current Wrexham County Borough Council specification with post top mounted at 0° tilt, Vision Illumination Valiant (LKD-VAL-95050SP) 1.47klm Warm White 2700k 9w LED luminaire, complete with rear shield and with Royce Thompson Oasis 1000 one part photocell 35 lux (ratio 1:0.5) mounted in 7 pin NEMA socket	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	TOFCO F144DP single fuse, double pole cut-out	N/A