

B. J. Dixon I.Eng., M.I.E.T.,
Architectural Engineering

19 Thatch Meadow Drive
Market Harborough
Leicestershire
LE16 7XH

Tel: 01858 465985
Mob. 07710 232369

e-mail: barry.j.dixon@btinternet.com

1st June 2022

Mr. P. Tomlinson,
Hen Ysgol,
Church road,
Gwynfryn,
Wrexham
LI11 5TR

Dear Philip,

New Sewage Treatment, Cae Madog Farm, Gwynfryn

The trial pit excavated in the revised location shows a percolation rate of 1000 litres / sq. m. / hour (calculation is attached) . The accepted discharge rate for domestic purposes is 150 litres / person /day.

Assuming that the ground conditions tested can be utilised for treated effluent disposal it is evident that there is adequate capacity for a sewage treatment plant to accommodate the discharge from three properties.

Yours sincerely,



Barry Dixon