Cyfoeth Naturiol Cymru
Natural Resources Wales

Ein cyf/Our ref: CAS-283924-V1J7
Eich cyf/Your ref: P/2025/0498

Wrexham County Borough Council
The Guildhall
Wrexham
LL11 1AY

Dyddiad/Date: 16 July 2025

Annwyl Syr/Madam/Dear Sir/Madam,

BWRIAD/PROPOSAL: TROI'R ADEILAD ALLANOL YN RHANDY PRESWYL / CONVERSION OF OUTBUILDING INTO RESIDENTIAL ANNEXE

LLEOLIAD/LOCATION: HIGH ASH, LITTLE GREEN, BRONINGTON, WHITCHURCH, SY13 3HH

Thank you for consulting Cyfoeth Naturiol Cymru (CNC)/Natural Resources Wales (NRW) about the above, which we received on 03 July 2025.

We have concerns with the application as submitted because inadequate information has been provided in support of the proposal. To overcome these concerns, you should seek further information from the applicant regarding foul drainage. If this information is not provided, we would object to this planning application. Further details are provided below.

Protected Sites

Special Area of Conservation (SAC)

We note the application site is within the catchment of the River Dee and Bala Lake Special Area of Conservation (SAC). In line with our *Advice to Planning Authorities for Planning Applications Affecting Nutrient Sensitive River Special Areas of Conservation* (28 June 2024), under the Habitats Regulations, Planning Authorities must consider the impact of proposed developments on water quality within SAC river catchments. We therefore advise you to consider whether the proposals, as submitted, would increase the volume of foul discharge from the site in planning terms.

We note from the information submitted that the development has the potential to increase the amount of nutrients being discharged from the site. As such, we refer you to our Advice and advise you to seek further information from the applicant. We note that information has already been submitted in respect of confirming that both the existing dwelling and proposed dwelling would be connected to a new septic tank being installed as part of the proposals.

However, we advise you to seek further information as identified in the section titled *'What does this mean for development proposals involving private sewage treatment systems'* of that Advice.

We note that Drawing 80528/ GH / 003 dated 27/05/2025, Roger Parry & Partners shows the location of the proposed private sewage treatment system and drainage field. Where discharges to ground are proposed, developers should provide the results of infiltration testing with calculations to demonstrate that the drainage field size and design is appropriate for the volume of discharge proposed and follows the relevant British Standard.

Ultimately, the suitability of foul drainage arrangements for the proposed development is a matter for your Authority to determine. We therefore advise you to take the above into account in your determination of whether the development is likely to have a significant effect on the SAC. Should you determine that an Appropriate Assessment is required, the Applicant will then need to submit whatever evidence they deem appropriate (seeking advice from consultants as may be necessary) to demonstrate no adverse effect on site integrity.

Foul Drainage

Applicants wishing to operate a private sewerage system will need ***either*** to apply to us for an environmental permit ***or*** register with us for an exemption from the permit requirement. Septic tanks and small sewage treatment works that meet certain criteria may be registered as exempt.

The proposed development proposes private sewage treatment however the discharge location and method have not been confirmed. Disposing of treated sewage effluent to ground within 50 metres of a groundwater abstraction used for drinking water supply will require an environmental permit from NRW. Granting of planning permission does not guarantee that NRW will issue a permit. Further information is available at Natural Resources Wales / Septic tanks and private sewage systems

Further information may be needed as part of the application process for an environmental permit. The Applicant is therefore advised to contact us for pre-application advice at the earliest opportunity to try to ensure that there is no conflict between any planning permission granted and the permit requirements. Further details on how to access our pre-application advice service can be found here.

It is important to note that a grant of planning permission does not guarantee that a permit will be granted. A proposal may be deemed unacceptable either because of environmental risk or because upon further investigation, a connection to mains sewer was feasible. Applicants are encouraged to ensure they have all the required permissions, consents, permits and any other approvals in place prior to commencement of works on the site.

Where private sewage treatment/disposal facilities are utilised, they must be installed and maintained in accordance with British Standard 6297 and Approved Document H of the Building Regulations. We also refer the Applicant to Guidance for Pollution Prevention 4 on the NetRegs website, which provides further information.

Other Matters

Our comments above only relate specifically to matters included on our checklist, *Development Planning Advisory Service: Consultation Topics* (September 2018), which is

published on our website. We have not considered potential effects on other matters and do not rule out the potential for the proposed development to affect other interests.

We advise the applicant that, in addition to planning permission, it is their responsibility to ensure they secure all other permits/consents/licences relevant to their development. Please refer to our website for further details.

If you have any queries on the above, please do not hesitate to contact us.

Yn gywir / Yours faithfully,

Rachael Burke
Cynghorydd - Cynllunio Datblygu/Advisor - Development Planning
Cyfoeth Naturiol Cymru/Natural Resources Wales

E-bost/E-mail: northplanning@cyfoethnaturiolcymru.gov.uk

Croesewir gohebiaeth yn Gymraeg a byddwn yn ymateb yn Gymraeg, heb i hynny arwain at oedi./Correspondence in Welsh is welcomed, and we will respond in Welsh without it leading to a delay.