



Ty'n-y-Pistyll
Glyndyfrdwy
Corwen
Denbighshire
LL21 9BP
Tel: 01490 430 308
Mob: 07714 155 177
VAT No.: 932657214

PERCUATION TEST RESULTS

Date – 22nd January 2025

Location – Plas Nantyr Field

Weather Condition – Dry

Operative – Paul Davies

TEST RESULTS AVERAGE (Minutes)

Test Hole Number	1	2	3
3 x Tests Per Hole (Minutes)	26	37	74
	32	39	82
	41	50	69
Hole Average (Minutes)	33	42	75

$$33 + 42 + 75 = 150 / 3 = 50 \times 60 = 3000 / 150 = 20VP$$