

Ein cyf/Our ref: CAS- 250456-H7H1
Eich cyf/Your ref: P/2024/0113

Wrexham County Borough Council
The Guildhall
Wrexham
LL11 1AY

Dyddiad/Date: 20 March 2024

Dear Mr Greenland,

BWRIAD/PROPOSAL: CAIS AMLINELLLOL AR GYFER CODI ANNEDD (AND GARAGE) (CADW POB MATER) / OUTLINE APPLICATION FOR ERECTION OF DWELLING AND GARAGE (ALL MATTERS RESERVED)

LLEOLIAD/LOCATION: BRAEMORE, HILL STREET, CEFN MAWR, WREXHAM, LL14 3BB

Thank you for consulting Cyfoeth Naturiol Cymru (CNC)/Natural Resources Wales (NRW) about the above, which we received on 29 February 2024.

We have concerns with the application as submitted because inadequate information has been provided in support of the proposal. To overcome these concerns, you should seek further information from the applicant regarding foul drainage. If this information is not provided, we would object to this planning application. Further details are provided below.

Foul Drainage

We note the application site is within the catchment of the River Dee and Bala Lake Special Area of Conservation (SAC). As you are aware, on the 21st January 2021, we published an evidence package outlining phosphorus levels for all river SACs across Wales. In line with our [Planning Advice](#) (August 2023), under the Habitats Regulations, Planning Authorities must consider the phosphorus impact of proposed developments on water quality within SAC river catchments. We therefore advise you to consider whether the proposals, as submitted, would increase the volume of foul discharge from the site in planning terms.

We note the method of foul drainage has not been confirmed. However, as you are aware, the site is within a sewered area.

The installation of private sewage treatment facilities within publicly sewered areas is not normally considered environmentally acceptable because of the greater risk of failures leading to pollution of the water environment compared to public sewerage systems.

Section 6.6.21 of Planning Policy Wales states 'Any development discharging domestic sewage should connect to the foul sewer where it is reasonable to do so. Development

proposing the use of non-mains drainage schemes will only be considered acceptable where connection to the main sewer is not feasible...'

Government guidance on private sewerage in Welsh Government Circular 008/2018 stresses that the first presumption must be to provide a system of foul drainage discharging into a public sewer. Only where having taken into account the cost and/or practicability it can be shown to the satisfaction of the local planning authority that connection to a public sewer is not feasible, should non-mains foul sewage disposal solutions be considered.

We therefore advise the Applicant to confirm that the foul drainage is connected to the mains sewerage system.

The Applicant should thoroughly investigate the possibility of connecting to the foul sewer by taking the following steps:

- Approach the sewerage undertaker to reach an agreement for a connection to the foul sewer.
- If the sewerage undertaker refuses connection to the public sewer, request that they adopt the proposed treatment system.
- If the sewerage undertaker refuses both of the above, you must appeal the refusal with Ofwat.

For further details please see [Natural Resources Wales / Private sewage treatment in an area with a public sewer](#)

The Applicant should be aware that should a connection to the mains sewer not be feasible, they will also need to demonstrate that the proposal would not pose an unacceptable risk to the water environment. Welsh Government Circular 008/2018 advises that a full and detailed consideration be given to the environmental criteria listed under paragraph 2.6 of the Circular, in order to justify the use of private sewerage.

As stated above, we expect developers discharging domestic sewage to connect to the public foul sewer where it is reasonable to do so. We will not normally grant a discharge permit for a private sewage treatment system where it is reasonable to connect to the public foul sewer. We also expect discharges of trade effluent to connect to the public foul sewer where it is reasonable to do so and subject to the sewerage undertaker granting a trade effluent consent or entering into a trade effluent agreement.

Furthermore, we refer you to the section in our Planning Advice titled 'What does this mean for development proposals involving connection to public wastewater treatment works'.

Ultimately, the suitability of foul drainage arrangements for the proposed development is a matter for your Authority to determine.

Should your Authority conclude that the proposal is likely to have a significant effect on the River Dee and Bala Lake SAC, please consult us on your Appropriate Assessment under Regulation 63 of the Conservation of Habitats and Species Regulations 2017 (as amended).

Protected Species

We note that the bat report submitted in support of the above application (Ecological Impact Assessment, BRA241123, 24/01/2024) has identified that bats are not roosting at the application site, but use the site for commuting and foraging. From the information submitted, we consider that the proposed development represents a lower risk for bats, as defined in our guidance document '*Natural Resources Wales Approach to Bats and Planning* (2015)'. Bats and their breeding and resting places are protected under the Conservation of Habitats and Species Regulations 2017.

As this is a lower risk case for bats, we consider that the development is not likely to be detrimental to the maintenance of the population of the species concerned at a favourable conservation status in its natural range.

The report has recommended that a lighting plan be provided. We advise that you liaise with your internal ecological adviser for further advice.

Please consult us again if any further information shows that this is no longer a lower risk case.

Other Matters

Our comments above only relate specifically to matters included on our checklist, *Development Planning Advisory Service: Consultation Topics* (September 2018), which is published on our [website](#). We have not considered potential effects on other matters and do not rule out the potential for the proposed development to affect other interests.

We advise the applicant that, in addition to planning permission, it is their responsibility to ensure they secure all other permits/consents/licences relevant to their development. Please refer to our [website](#) for further details.

If you have any queries on the above, please do not hesitate to contact us.

Yours faithfully,

Gareth Thomas

Cynghorydd - Cynllunio Datblygu/Advisor - Development Planning

Cyfoeth Naturiol Cymru/Natural Resources Wales

E-bost/E-mail: northplanning@cyfoethnaturiolcymru.gov.uk

Croesewir gohebiaeth yn Gymraeg a byddwn yn ymateb yn Gymraeg, heb i hynny arwain at oedi./Correspondence in Welsh is welcomed, and we will respond in Welsh without it leading to a delay.