



MEMORANDUM

From: Ian Jones

To: Matthew Phillips

**Head of Service Public Protection
Service Planning Development**

Head of

Our Ref:

Your Ref: P/2023/0631

Date: 24-11-2023

Town and Country Planning Act 1990

Town and Country Planning (General Development Procedure) Order 1996

Re: P/2023/0631, JOHNSTOWN JUNIOR SCHOOL BANGOR ROAD JOHNSTOWN

**GOSOD SIMNAI MEWN CEGIN FASNACHOL (OL-WEITHREDOL) / INSTALLATION OF FLUE
TO COMMERCIAL KITCHEN (IN RETROSPECT)**

RPT1 - REPORT REVIEW

Report Ysgol-Yr-Hafod Primary School, Kitchen Extract Noise Impact Assessment by PDA. Dated January 2023 has modelled the noise levels to be 10dB lower than the background noise at the nearest noise sensitive property hence inaudible. The findings of this report are accepted

ZP05 - NOISE GENERATION - NOISE LEVEL CONDITION

The rating level of any noise generated by reason of this development shall not exceed the pre-existing background level at any time. The noise levels shall be determined at nearby noise sensitive premises, and

measurements and assessment shall be made in accordance with BS4142:2014 Methods for Rating and Assessing Industrial and Commercial Sound.

.....

Head of Service Public Protection