

Ellie Jones

From: North Planning <NorthPlanning@cyfoethnaturiolcymru.gov.uk>
Sent: 26 February 2024 10:57
To: planning_admin
Subject: P/2023/0255 - Penley Mill, Lions Lane, Penley, Wrexham, LL13 0LY (Minor) v3 - NRW
Response NRW:00948778

Follow Up Flag: Follow up
Flag Status: Completed

Hello Simon,

Thank you for this additional information. We note that the additional information shows that the applicant has been granted an exemption for a discharge to ground for less than 2 cubic meters of foul effluent a day. Therefore, if they present a plan in line with this exemption (with the discharge to ground in the location registered with the exemption), we would not object to the application. Currently, a cesspool is proposed, and previous to that a discharge to the watercourse was proposed (which would not be in line with the exemption they have now obtained).

Kind Regards
Ruth Prichard

Tîm Cynllunio Datblygu / Development Planning Team
Cyfoeth Naturiol Cymru / Natural Resources Wales

Ffôn / Tel: 03000 653787
www.cyfoethnaturiolcymru.gov.uk / www.naturalresourceswales.gov.uk

Yn falch o arwain y ffordd at ddyfodol gwell i Gymru trwy reoli'r amgylchedd ac adnoddau naturiol yn gynaliadwy / Proud to be leading the way to a better future for Wales by managing the environment and natural resources sustainably.

Croesewir gohebiaeth yn Gymraeg a byddwn yn ymateb yn Gymraeg, heb i hynny arwain at oedi / Correspondence in Welsh is welcomed, and we will respond in Welsh without it leading to a delay.