



MEMORANDUM

From: Ian Jones

**Head of Service Public Protection
Service Planning Development**

Our Ref:

Date: 28-05-2024

To: Matthew Phillips

Head of

Your Ref: P/2024/0333

Town and Country Planning Act 1990

Town and Country Planning (General Development Procedure) Order 1996

Re: P/2024/0333, SNOWDON HALL VICARAGE HILL WREXHAM

**CODI STRWYTHUR PERGOLA A PHAFILIWN YN YR ARDAL AMWYNDER ALLANOL,
GWNEUD GWELLIANNAU TIRLUNIO A GOSOD CYFLEUSTERAU STORIO BINIAU /
ERECTION OF PAVILION AND PERGOLA STRUCTURE TO EXTERNAL AMENITY AREA,
LANDSCAPING IMPROVEMENTS AND INSTALLATION OF BIN STORE FACILITIES**

A22NA – MINOR DEMOLITION CONSTRUCTION NOISE

All works in relation to the implementation of this permission, including deliveries to and /or leaving the site, should be undertaken only between the hours of 07.30 to 18.00 Monday to Friday, 08.00 to 14.00 on a Saturday, and at no time on a Sunday or a Bank Holiday. Outside these times, any works which are audible beyond the site boundary have the potential to cause unreasonable disturbance to neighbouring premises.

The applicant is advised that the Council has the option to control construction noise by serving a Control of Pollution Act 1974, Section 60 Notice where deemed necessary, and failure to comply with such a Notice can

result in prosecution.

The applicant is further advised that any complaints received relating to noise of any type from the development may also be investigated using the Council's Standardised Procedure for Dealing with Noise Nuisance Complaints. This is done under the Statutory Nuisance provisions provided within the Environmental Protection Act 1990, and legal action may be taken where appropriate.

The applicant must adhere to the times given above wherever possible. If, however, there are urgent or unavoidable circumstances requiring work outside of the specified times, permission to proceed may be sought by contacting Environmental Health & Housing Standards at healthandhousing@wrexham.gov.uk or 01978 292040. Please use the same contact details for any other enquiries regarding construction / demolition site noise.

Environmental Protection - No Comments

Odour from cooking has the potential for classification as a statutory nuisance under the Environment Protection Act 1990. If odour is found to be causing a nuisance then an Abatement Notice may be served, and the applicant is advised to consider this when designing the installation..

A23N - BURNING OF WASTE

Burning of waste generated from construction activities is not considered to be an appropriate method of disposal and action may be taken as follows:

- Under the Environmental Protection Act 1990 anyone found disposing of construction site waste by burning is likely to be in breach of their duty of care with regard to waste disposal;
- Under the same Act an abatement notice may be served where smoke is judged to be causing a nuisance to neighbouring properties. Failure to comply with the requirements of the notice can result in prosecution;
- Under the Clean Air Act 1993 it is an offence for a commercial activity to burn anything that gives rise to dark smoke.

To prevent offences under the above named Acts there should be no bonfires on the site, to include the prohibition of the burning of cleared vegetation. The applicant should contact the Council's Environmental Health & Housing Standards Team on healthandhousing@wrexham.gov.uk or 01978 292040 for further advice and information.

A32N - FOOD PREMISES – FOG ADVICE

Guidance on best management practice for catering outlet for the dispersal of fats, oils, grease and food waste, as issued by Water UK is available by contacting the Council's Environmental Health & Housing Standards Team on healthandhousing@wrexham.gov.uk or 01978 298989 for further advice and information.

A28N - ILLUMINATION / LIGHTING Lighting has the potential for classification as a statutory nuisance under the Environment Protection Act 1990. If lighting is found to be causing a nuisance then an Abatement Notice may be served, and the applicant is advised to consider this when designing the installation of any lighting. **ZP16 - GREASE TRAPS**

Prior to first use of the development a suitable grease trap shall be provided in order to prevent entry into the public sewerage system of matter (cooking fats, oils and grease etc.) likely to interfere with the free flow of the sewer contents, or which would prejudicially affect the treatment and disposal of such contents. The grease trap shall thereafter be permanently retained in a working condition.

.....

Head of Service Public Protection