

MEMORANDUM



From:	Chief Officer, Environment & Technical	To:	Chief Officer Economy & Planning
		FAO::	Simon Greenland
Our Ref:	ET/DC/DB/P/2024/0229	Your Ref:	P/2024/0229
Date:	31/07/24		

TOWN AND COUNTRY PLANNING ACT 1990

TYNNU AMOD 3 CANIATÂD CYNLLUNIO P/2019/0629 / REMOVAL OF CONDITION 3 OF PLANNING PERMISSION P/2019/0629

BRYN AWEN FRON HEULOG HILL BWLCHGWYN WREXHAM
Grid Ref: E 326091N 353082

I refer to your consultation / email dated 22/04/2024 in respect of the above.

We refer to Highways response dated 10th September 2024 relating to this application and note that we have no objection subject to:

1. The entrance should be hard paved and no gates installed for a minimum of 5m depth into the property.
2. The pedestrian access referred to previously should not be used for vehicles

Traffic, visibility, parking are all acceptable as previously noted.

We enclose Highway Guidance Note for reference when carrying out any works on or immediately adjacent to the highway.

Chief Officer, Environment & Technical

Appendix

Highways Development Control Standard Advisory Note

In the interests of maintaining highway safety, and to avoid obstruction of the public highway (in contravention of the Highways Act), The Applicant is advised to coordinate with the highway

authority at highwayroadworks@wrexham.gov.uk in advance of commencement of the development/works with respect to:

1. Skip, scaffolding, hoarding or A frame/signage (Permit required for these items, if on the public highway);
2. Use of a parking space for a set down/delivery area;
3. Record a dilapidation survey of the adjacent carriageway prior to commencement (to avoid being asked to repair damage by the Applicant whilst carrying out their works);
4. If any lane closure or obstruction of the highway is required for a crane or similar;
5. Protection against dust and debris blowing onto the public highway
6. Construction traffic parking locally avoiding nuisance to others;
7. If the Applicant's scope of work includes new apparatus in the highway, such as new mains services then a Section 50 licence will be required. *Insurances and demonstration of competency to carry out works in the public highway will be required.*
8. Lowering of kerbs or minor pavement alterations require Section 184 agreement. *Insurances and demonstration of competency to carry out works in the public highway will be required.*
9. A section 278 agreement works agreement is required for more significant alterations to the existing highway
10. Any temporary works affecting traffic lights, [pedestrian/cycle road crossings, or bus stops require pre-planning and permits;
11. For applications with a private driveway (either existing or proposed) connecting onto the public highway, the following conditions of approval apply:
 - No surface water from the applicants site should be allowed to drain onto the public highway,
 - The first 5m* minimum (for residential property) should be hard paved, avoiding gravel or loose chippings from spreading.
 - No gate should be built in a location where it would result in a car obstructing the highway whilst being unlocked, and it should not swing out and over a pavement or any other part of the highway.

*The hard paved length and set back if required is subject to the applicants proposed vehicular length

The applicants should allow a minimum of 4 weeks' notice for any of the above standard requirements, and 6-8 weeks for lane closures & road closures (lead times may change without notice subject to workload and complexity). Any works involving Trunk roads should be coordinated separately and directly with the North & Mid Wales trunk Road Agency. For larger sites with a significant impact upon the highway, a Construction Traffic Management Plan will be required.