



MEMORANDUM

From: Ian Jones
**Head of Service Public Protection
Economy and Planning**

To: David Fitzsimon
Chief Officer

Our Ref:

Your Ref: P/2023/0460

Date: 24-08-2023

Town and Country Planning Act 1990

Town and Country Planning (General Development Procedure) Order 1996

Re: P/2023/0460, 1A NEW HIGH STREET RUABON WREXHAM

CONVERSION OF UPPER FLOOR INTO RESIDENTIAL FLAT

ZP09 - SOUNDPROOFING OF A BUILDING (BETWEEN FLOORS/WALLS)

No part of the development shall commence until a scheme of noise insulation and attenuation measures between the walls with neighboring commercial units and the floors. in compliance with Building Regulations Guidance: Part E - Resistance to the Passage of Sound, has been submitted to, and approved in writing by, the Local Planning Authority. The measures as are approved shall be fully implemented in strict accordance with the scheme prior to first occupation / use of the development and shall thereafter be permanently retained.

ZP07A NOISE SURVEY

No part of the development shall commence until a noise survey has been carried out, and a detailed report of the survey findings has been submitted to, and approved in writing by, the Local Planning Authority. The noise survey shall determine noise levels for both Day (07:00 – 23:00 hours) and Night (23:00 – 07:00 hours), having regard to Planning Policy Wales (PPW) Guidance, Technical Advice Note (TAN) 11 – Noise. The report of the noise survey findings shall include:

a) Noise levels arising from day / night time activities in the vicinity of the proposed development site and the impact upon the existing or proposed accommodation, and

b) A detailed scheme of noise insulation and / or attenuation measures so designed to safeguard the amenity of the existing or occupants of the proposed accommodation hereby approved.

The measures as are approved shall be fully implemented prior to the first occupation / use of the development.

.....

Head of Service Public Protection