

Ein cyf/Our ref: CAS-248002-T7S3
Eich cyf/Your ref: P/2024/0001

Wrexham County Borough Council
The Guildhall
Wrexham
LL11 1AY

Dyddiad/Date: 02 February 2024

Annwyl / Dear Ms Perkins,

BWRIAD/PROPOSAL: Change of use of building from class B1 (office) to class A1 (beauty salon)

LLEOLIAD/LOCATION: Bridge House, Station Road, Rossett, Wrexham, LL12 0HE

Thank you for consulting Cyfoeth Naturiol Cymru (CNC)/Natural Resources Wales (NRW) about the above, which we received on 29 January 2024.

We have concerns with the application as submitted because inadequate information has been provided in support of the proposal. To overcome these concerns, you should seek further information from the applicant regarding foul drainage. If this information is not provided, we would object to this planning application. Further details are provided below.

Protected Sites and Foul Drainage

We note the application site is within the catchment of the River Dee Special Area of Conservation (SAC). As you are aware, on the 21st January 2021, we published an evidence package outlining phosphorus levels for all river SACs across Wales. In line with our [Planning Advice](#) (August 2023), under the Habitats Regulations, Planning Authorities must consider the phosphorus impact of proposed developments on water quality within SAC river catchments. We therefore advise you to consider whether the proposals, as submitted, would increase the volume of foul discharge from the site in planning terms.

We note from the information submitted that the development has the potential to increase the amount of phosphorus being discharged from the site. As such, we refer you to our Planning Advice and advise you to seek further information from the applicant. We note that information has already been submitted confirming that foul waste would be managed with a mains connection. However, we advise you to seek further information as identified in the section titled 'What does this mean for development proposals involving connection to public wastewater treatment works' of that advice.

Provided this advice is followed and you are able to conclude that the development is not likely to have a significant effect on the SAC, we would have no objection to the proposal. However, should you conclude that the proposed development is likely to have a

significant effect on the SAC, please consult us on your Appropriate Assessment under Regulation 63 of the Conservation of Habitats and Species Regulations 2017 (as amended).

Flood Risk

Our Flood Risk Map confirms the application site lies entirely within Zone C1 of the Development Advice Maps (DAM) as contained in Technical Advice Note (TAN) 15: Development and Flood Risk (2004). The Flood Map for Planning identifies the application site to be at risk of flooding and falls into Flood Zone 3 (Rivers).

Given the nature of the proposed development (and in the absence of a flood consequences assessment) we consider the proposals could be acceptable, subject to the developer being made aware of the potential flood risks and advised to install flood-proofing measures as part of the development.

In areas at risk of flooding, we recommend that consideration be given to the incorporation of flood resistance/resilience measures into the design and construction of the development. These could include flood barriers on ground floor doors, windows and access points, implementation of suitable flood proofing measures to the internal fabric of the ground floor and locating electrical sockets/components at a higher level above possible flood levels.

We refer the applicant to our [website](#) for further advice and guidance. Additional guidance including the leaflet "Prepare your Property for flooding" can be found [here](#).

The developer can also access advice and information on protection from flooding from the ODPM publication 'Preparing for Floods: Interim Guidance for Improving the Flood Resistance of Domestic and Small Business Properties' [here](#).

Protected Species

We note that there is no information about protected species with the application and, therefore, are assuming that your Authority has screened the application and concluded that there is not a reasonable likelihood of protected species being present.

Other Matters

Our comments above only relate specifically to matters included on our checklist, *Development Planning Advisory Service: Consultation Topics* (September 2018), which is published on our [website](#). We have not considered potential effects on other matters and do not rule out the potential for the proposed development to affect other interests.

We advise the applicant that, in addition to planning permission, it is their responsibility to ensure they secure all other permits/consents/licences relevant to their development. Please refer to our [website](#) for further details.

If you have any queries on the above, please do not hesitate to contact us.

Yn ddifffuant / Yours sincerely,

Alex Homer

Cynghorydd - Cynllunio Datblygu/Advisor - Development Planning
Cyfoeth Naturiol Cymru/Natural Resources Wales

E-bost/E-mail: MidPlanning@cyfoethnaturiolcymru.gov.uk

Croesewir gohebiaeth yn Gymraeg a byddwn yn ymateb yn Gymraeg, heb i hynny arwain at oedi./Correspondence in Welsh is welcomed, and we will respond in Welsh without it leading to a delay.