

Ein cyf/Our ref: CAS-252029-N4L7
Eich cyf/Your ref: P/2023/0255

Wrexham County Borough Council
The Guildhall
Wrexham
LL11 1AY

Date: 28 March 2024

Dear Sir/Madam,

**PROPOSAL: INSTALLATION OF BIO-DISC BA SEWAGE TREATMENT PLANT WITH
OUTFALL TO EXISTING STORM DRAIN**

LOCATION: PENLEY MILL, LIONS LANE, PENLEY, WREXHAM, LL13 0LY

Thank you for consulting Cyfoeth Naturiol Cymru (CNC)/Natural Resources Wales (NRW) about the above, which we received on 21 March 2024.

We have no objection to the proposed development as submitted and provide the following advice.

Protected Sites

Foul drainage

We note the application site is within the catchment of the River Dee and Bala Lake Special Area of Conservation (SAC). As you are aware, on the 21st January 2021, we published an evidence package outlining phosphorus levels for all river SACs across Wales. In line with our [Planning Advice](#) (August 2023), under the Habitats Regulations, Planning Authorities must consider the phosphorus impact of proposed developments on water quality within SAC river catchments. We therefore advise you to consider whether the proposals, as submitted, would increase the volume of foul discharge from the site in planning terms.

However, recognising the specific nature of the application submitted private sewage treatment system as set out in proposed site plan (October 2023) DRG No 722804. In addition the site has an Environmental Permitting (England and Wales) Regulations 2010 Water Discharge Exemption (NRW-WQE095802) for the discharge as such we are satisfied that it is unlikely to increase the amount of phosphorus entering the catchment. Therefore, we are satisfied that the proposal is not likely to have a significant effect on the River Dee and Bala Lake SAC.

Other Matters

Our comments above only relate specifically to matters included on our checklist, *Development Planning Advisory Service: Consultation Topics* (September 2018), which is published on our [website](#). We have not considered potential effects on other matters and do not rule out the potential for the proposed development to affect other interests.

We advise the applicant that, in addition to planning permission, it is their responsibility to ensure they secure all other permits/consents/licences relevant to their development. Please refer to our [website](#) for further details.

If you have any queries on the above, please do not hesitate to contact us.

Yours faithfully

Ruth Prichard

Cynghorydd - Cynllunio Datblygu/Advisor - Development Planning
Cyfoeth Naturiol Cymru/Natural Resources Wales

E-bost/E-mail: northplanning@cyfoethnaturiolcymru.gov.uk
Ffôn/Phone: 03000 65 3787

Croesewir gohebiaeth yn Gymraeg a byddwn yn ymateb yn Gymraeg, heb i hynny arwain at oedi./Correspondence in Welsh is welcomed, and we will respond in Welsh without it leading to a delay.