



MEMORANDUM

From: Ian Jones

To: Matthew Phillips

**Head of Service Public Protection
Service Planning Development**

Head of

Our Ref:

Your Ref: P/2024/0095

Date: 18-03-2024

Town and Country Planning Act 1990

Town and Country Planning (General Development Procedure) Order 1996

Re: P/2024/0095, 46 VICTORIA ROAD WREXHAM

GOSOD UNED AERDYMHERU / INSTALLATION OF AIR CONDITIONING UNIT

ZP05 - NOISE GENERATION - NOISE LEVEL CONDITION

The rating level of any noise generated by reason of this development shall not exceed the pre-existing background level at any time. The noise levels shall be determined at nearby noise sensitive premises, and measurements and assessment shall be made in accordance with BS4142:2014 Methods for Rating and Assessing Industrial and Commercial Sound.

.....

Head of Service Public Protection