

Ellie Jones

From: Grace Lewis <Grace.Lewis@networkrail.co.uk>
Sent: 18 January 2024 14:13
To: planning
Subject: P/2023 /0300 - GER Y GORSAF NEWBRIDGE ROAD NEWBRIDGE WREXHAM

Follow Up Flag: Follow up
Flag Status: Completed

OFFICIAL



Network Rail
1st Floor
Bristol Temple Point
Bristol
BS1 6NL

My Ref: P/TP24/03
Your Ref: P/2023 /0300

Date: 18 January 2024

TOWN AND COUNTRY PLANNING ACT 1990 (as amended)

APPLICATION NO: P/2023 /0300

PROPOSAL: ERECTION OF DETACHED GARAGE WITH SUN TERRACE ROOF AND LINK WALKWAY FROM NEW BALCONY TO LOUNGE. NEW BALCONY OFF DINING ROOM. EXTENSION TO GARDEN

LOCATION: GER Y GORSAF NEWBRIDGE ROAD NEWBRIDGE WREXHAM

Dear Sir/Madam,

Thank you for your email dated **10 January 2024** together with the opportunity to comment on this proposal.

Network Rail has no objection in principle to the above proposal but due to the proposal being next to Network Rail land and our infrastructure and to ensure that no part of the development adversely impacts the safety, operation and integrity of the operational railway we have included asset protection comments which the applicant is strongly recommended to action should the proposal be granted planning permission.

Any works on this land will need to be undertaken following engagement with Asset Protection to determine the interface with Network Rail assets, buried or otherwise and by entering into a Basic Asset Protection Agreement, if required, with a minimum of 3months notice before works start. Initially the outside party should contact assetprotectionwales@networkrail.co.uk.

DRAINAGE

Soakaways / attenuation ponds / septic tanks etc, as a means of storm/surface water disposal must not be constructed near/within 5 metres of Network Rail's boundary or at any point which could adversely affect the stability of Network Rail's property/infrastructure. Storm/surface water must not be discharged onto Network Rail's property or into Network Rail's culverts or drains. Network Rail's drainage system(s) are not to be compromised by any work(s). Suitable drainage or other works must be provided and maintained by the Developer to prevent surface water flows or run-off onto Network Rail's property / infrastructure. Ground levels – if altered, to be such that water flows away from the railway. Drainage does not show up on Buried service checks.

GROUND LEVELS

The developers should be made aware that Network Rail needs to be consulted on any alterations to ground levels. No excavations should be carried out near railway embankments, retaining walls or bridges.

FOUNDATIONS

Network Rail offers no right of support to the development. Where foundation works penetrate Network Rail's support zone or ground displacement techniques are used the works will require specific approval and careful monitoring by Network Rail. There should be no additional loading placed on the cutting and no deep continuous excavations parallel to the boundary without prior approval.

GROUND DISTURBANCE

The works involve disturbing the ground on or adjacent to Network Rail's land it is likely/possible that the Network Rail and the utility companies have buried services in the area in which there is a need to excavate. Network Rail's ground disturbance regulations applies. The developer should seek specific advice from Network Rail on any significant raising or lowering of the levels of the site.

EXCAVATIONS/EARTHWORKS

All excavations / earthworks carried out in the vicinity of Network Rail's property / structures must be designed and executed such that no interference with the integrity of that property / structure can occur. If temporary compounds are to be located adjacent to the operational railway, these should be included in a method statement for approval by Network Rail.

Yours Sincerely,

Grace Lewis

Town Planning Technician Wales and Western
Network Rail
Temple Point, Redcliffe Way, Bristol, BS1 6NL
E grace.lewis@networkrail.co.uk
www.networkrail.co.uk/property

The content of this email (and any attachment) is confidential. It may also be legally privileged or otherwise protected from disclosure.

This email should not be used by anyone who is not an original intended recipient, nor may it be copied or disclosed to anyone who is not an original intended recipient.

If you have received this email by mistake, please notify us by emailing the sender, and then delete the email and any copies from your system.

Liability cannot be accepted for statements made which are clearly the sender's own and not made on behalf of Network Rail.

Network Rail Infrastructure Limited registered in England and Wales No. 2904587, registered office Network Rail, Waterloo General Office, London, SE1 8SW.

