

Ein cyf/Our ref: CAS-243449-X9B7
Eich cyf/Your ref: P/2023/0772

Wrexham County Borough Council
The Guildhall
Wrexham
LL11 1AY

Dyddiad/Date: 06 December 2023

Annwyl Syr/Madam/Dear Sir/Madam,

BWRIAD/PROPOSAL: Rhyddhau amod 8 (draenio) o apêl i benderfyniad app/h6955/a/19/3221887 (p/2018/0613) discharge of condition 8 (drainage) of appeal decision app/h6955/a/19/3221887 (p/2018/0613)

LLEOLIAD/LOCATION: Land Adjacent To, Graig Wen Farm, Off Brymbo Road, Bwlchgwyn, Wrexham, LL11 5UB

Thank you for consulting Cyfoeth Naturiol Cymru (CNC)/Natural Resources Wales (NRW) about the above, which we received on 23 November 2023.

We have concerns with the application as submitted. We do not recommend your Authority discharges condition 8 for the following reasons.

Condition 8

We note the application site is within the catchment of the River Dee and Bala Lake Special Area of Conservation (SAC). As you are aware, on the 21st January 2021, we published an evidence package outlining phosphorus levels for all river SACs across Wales. In line with our [Planning Advice](#) (August 2023), under the Habitats Regulations, Planning Authorities must consider the phosphorus impact of proposed developments on water quality within SAC river catchments. We therefore advise you to consider whether the proposals, as submitted, would increase the volume of foul discharge from the site in planning terms.

We note from the information submitted that the development has the potential to increase the amount of phosphorus being discharged from the site. As such, we refer you to our Planning Advice and advise you to seek further information from the applicant. We note that information has already been submitted in respect of a private package treatment plant discharging to a drainage mound. However, we advise you to seek further information as identified in the section titled 'What does this mean for development proposals involving connection to public wastewater treatment works' and 'What does this mean for development proposals involving private sewage treatment systems' of that advice.

Furthermore, whilst the intention is to dispose of foul drainage to a private package treatment plant discharging to a drainage mound, according to our records the proposed development is located within a publicly sewered area.

The installation of private sewage treatment facilities within publicly sewered areas is not normally considered environmentally acceptable because of the greater risk of failures leading to pollution of the water environment compared to public sewerage systems.

Section 6.6.21 of Planning Policy Wales states 'Any development discharging domestic sewage should connect to the foul sewer where it is reasonable to do so. Development proposing the use of non-mains drainage schemes will only be considered acceptable where connection to the main sewer is not feasible...'

Government guidance on private sewerage in Welsh Government Circular 008/2018 stresses that the first presumption must be to provide a system of foul drainage discharging into a public sewer. Only where having taken into account the cost and/or practicability it can be shown to the satisfaction of the local planning authority that connection to a public sewer is not feasible, should non-mains foul sewage disposal solutions be considered.

We therefore advise the Applicant to either amend their proposals to ensure that the foul drainage is connected to the mains sewerage system or provide detailed evidence to demonstrate that it is not reasonable to connect.

The Applicant should thoroughly investigate the possibility of connecting to the foul sewer by taking the following steps:

- Formally approach the sewerage undertaker regarding a connection under Section 106 or a requisition under Section 98 of the Water Industry Act (WIA) 1991.
- Serve notice for connection under Section 106 of the WIA 1991 if the sewerage undertaker has refused connection.
- Provide details of the reasons given by the sewerage undertaker if it has refused connection under section 98 or section 106 of the WIA 1991 and confirmation that they have appealed against this decision.
- Demonstrate that it is not reasonable to connect to the public foul sewer.
- Where it is not reasonable to connect to the public foul sewer, demonstrate that they have considered requesting that the sewerage undertaker adopt their proposed system.

The Applicant should be aware that should a connection to the mains sewer not be feasible, they will also need to demonstrate that the proposal would not pose an unacceptable risk to the water environment. Welsh Government Circular 008/2018 advises that a full and detailed consideration be given to the environmental criteria listed under paragraph 2.6 of the Circular, in order to justify the use of private sewerage.

As stated above, we expect developers discharging domestic sewage to connect to the public foul sewer where it is reasonable to do so. We will not normally grant a discharge permit for a private sewage treatment system where it is reasonable to connect to the public foul sewer. We also expect discharges of trade effluent to connect to the public foul sewer

where it is reasonable to do so and subject to the sewerage undertaker granting a trade effluent consent or entering into a trade effluent agreement.

Applicants wishing to operate a private sewerage system will need either to apply to us for an environmental permit or register with us for an exemption from the permit requirement. Septic tanks and small sewage treatment works that meet certain criteria may be registered as exempt.

A step by step guide to registering an exemption can be found on our [website](#).

If the septic tank or private sewage treatment system is not eligible for an exemption, the Applicant will need to apply for an environmental permit, further details can be found [here](#). Should a permit be required further information may be needed as part of that application process. The Applicant is therefore advised to contact us for pre-application advice at the earliest opportunity to try to ensure that there is no conflict between any planning permission granted and the permit requirements. Further details on how to access our pre-application advice service can be found [here](#).

It is important to note that a grant of planning permission does not guarantee that a permit will be granted. A proposal may be deemed unacceptable either because of environmental risk or because upon further investigation, a connection to mains sewer was feasible. Applicants are encouraged to ensure they have all the required permissions, consents, permits and any other approvals in place prior to commencement of works on the site.

Please note, a lack of capacity, or plans to improve capacity in the sewer, is not a valid reason for a sewerage undertaker to refuse connection under Section 106 of the Water Industry Act 1991 and we may refuse to issue an environmental permit or exemption for private treatment facilities in such circumstances.

Where private sewage treatment/disposal facilities are utilised, they must be installed and maintained in accordance with British Standard 6297 and Approved Document H of the Building Regulations. We also refer the Applicant to Guidance for Pollution Prevention 4 on the NetRegs [website](#), which provides further information

Should you conclude that the proposed development is likely to have a significant effect on the SAC, please consult us on your Appropriate Assessment under Regulation 63 of the Conservation of Habitats and Species Regulations 2017 (as amended).

Other Matters

Our comments above only relate specifically to matters included on our checklist, *Development Planning Advisory Service: Consultation Topics* (September 2018), which is published on our [website](#). We have not considered potential effects on other matters and do not rule out the potential for the proposed development to affect other interests.

We advise the applicant that, in addition to planning permission, it is their responsibility to ensure they secure all other permits/consents/licences relevant to their development. Please refer to our [website](#) for further details.

If you have any queries on the above, please do not hesitate to contact us.

Yn gywir / Yours faithfully

Rachael Burke

Cynghorydd - Cynllunio Datblygu/Advisor - Development Planning
Cyfoeth Naturiol Cymru/Natural Resources Wales

E-bost/E-mail: northplanning@cyfoethnaturiolcymru.gov.uk

Croesewir gohebiaeth yn Gymraeg a byddwn yn ymateb yn Gymraeg, heb i hynny arwain at oedi./Correspondence in Welsh is welcomed, and we will respond in Welsh without it leading to a delay.