

Ein cyf/Our Ref: CAS-226233-G1X9
Eich cyf/Your Ref: P/2023/0439

Wrexham County
Borough Council,
The Guildhall,
Wrexham,
LL11 1AY

Dyddiad/Date: 10 August 2023

Annwyl Syr/Madam / Dear Sir/Madam,

BWRIAD/PROPOSAL: OUTLINE APPLICATION FOR ERECTION OF 6 DWELLINGS, FORMATION OF VEHICLE ACCESS AND SCHOOL CAR PARK (APPEARANCE, LANDSCAPING, LAYOUT AND SCALE RESERVED)

LLEOLIAD/LOCATION: LAND OPPOSITE EYTON SCHOOL, EYTON, WREXHAM, LL13 0YD

Thank you for consulting Cyfoeth Naturiol Cymru (CNC) / Natural Resources Wales (NRW) about the above, which we received on 18/07/2023.

We continue to have concerns with the application as submitted because inadequate information has been provided in support of the proposal. To overcome these concerns, further consideration is required regarding foul drainage. Further details are provided below.

We also advise that based on the information submitted to date, a condition regarding protected sites should be attached to any planning permission granted. Without the inclusion of this condition, we would object to this planning application.

Protected Sites

Foul Drainage

We note the application site is within the catchment of the River Dee and Bala Lake Special Area of Conservation (SAC). As you are aware, on the 21st January 2021, we published an evidence package outlining phosphorus levels for all river SACs across Wales. In line with our [Planning Advice](#) (August 2023), under the Habitats Regulations, Planning Authorities must consider the phosphorus impact of proposed developments on water quality within SAC river catchments. We therefore advise you to consider whether the proposals, as submitted, would increase the volume of foul discharge from the site in planning terms.

This outline application for the erection of 6 dwellings and associated development proposes connection of foul water to the mains sewer. However, no information has been provided to confirm whether Dŵr Cymru/Welsh Water (DCWW) can accept the foul flows from the

proposed development. We refer you to our Planning Advice and the information set out in the section titled 'What does this mean for development proposals involving connection to public wastewater treatment works'.

Your Authority will need to take the above into account in your determination of whether the development is likely to have a significant effect on the SAC. Should you determine that an Appropriate Assessment is required, the Applicant will then need to submit whatever evidence they deem appropriate (seeking advice from consultants as may be necessary) to demonstrate no adverse effect on site integrity. You should then consult us on your Appropriate Assessment under Regulation 63 of the Conservation of Habitats and Species Regulations 2017 (as amended).

Ultimately, the suitability of foul drainage arrangements for the proposed development is a matter for your Authority to determine.

Special Area of Conservation (SAC)

We note the presence of a watercourse on site which provides a direct hydrological pathway to the River Dee SAC.

We have concerns that harm from the proposed development on the SAC cannot be ruled out.

To secure appropriate mitigation measures, we advise that the condition set out below should be attached to any planning permission for this development. Provided the development is carried out in accordance with those conditions, we do not consider that it will adversely affect the integrity of the SAC.

Condition 1: Protected Sites

No development shall commence until a Construction Environmental Management Plan (CEMP) has been submitted to and approved in writing by the Local Planning Authority. The CEMP should include:

- Construction methods: details of materials, how waste generated will be managed;
- General Site Management: details of the construction programme including timetable, details of site clearance; details of site construction drainage, containments areas, appropriately sized buffer zones between storage areas (of spoil, oils, fuels, concrete mixing and washing areas) and any watercourse or surface drain.
- Soil Management: details of topsoil strip, storage and amelioration for re-use.
- CEMP Masterplan: details of the extent and phasing of development; location of landscape and environmental resources; design proposals and objectives for integration and mitigation measures.
- Control of Nuisances: details of restrictions to be applied during construction including timing, duration and frequency of works; details of measures to minimise noise and vibration from piling activities, for example acoustic barriers; details of dust control measures; measures to control light spill and the conservation of dark skies.

- Resource Management: details of fuel and chemical storage and containment; details of waste generation and its management; details of water consumption, wastewater and energy use.
- Traffic Management: details of site deliveries, plant on site, wheel wash facilities.
- Pollution Prevention: demonstrate how relevant Guidelines for Pollution Prevention and best practice will be implemented, including details of emergency spill procedures and incident response plan.
- Details of the persons and bodies responsible for activities associated with the CEMP and emergency contact details.
- Landscape/ecological clerk of works to ensure construction compliance with approved plans and environmental regulations.

The CEMP shall be implemented as approved during the site preparation and construction phases of the development.

Justification: A CEMP should be submitted to ensure necessary management measures are agreed and implemented for the protection of the environment during construction.

As the competent authority under the Conservation of Habitats and Species Regulations 2017 (as amended), your authority must, before deciding to give consent for a project which is likely to have a significant effect on the SAC site, either alone or in combination with other plans or projects, make an appropriate assessment of the implications of the project for that site in view of its conservation objectives. You must for the purposes of the assessment consult NRW and have regard to any representations we make within such reasonable time as you specify. In the absence of that assessment, NRW cannot advise that the proposals would not result in an adverse effect upon the SAC site.

Protected Species

We note the Preliminary Ecological Appraisal submitted with the application (Arbor Vitae, 20/05/2022, Preliminary Ecological Appraisal, Land Opposite Eyton School) identifies that there is no evidence of bats or other protected species at the proposed site. We therefore have no comments to make on the application as submitted and advise that you liaise with your Authority's ecologist regarding the recommended practices.

Other Matters

Our comments above only relate specifically to matters included on our checklist, *Development Planning Advisory Service: Consultation Topics* (September 2018), which is published on our [website](#). We have not considered potential effects on other matters and do not rule out the potential for the proposed development to affect other interests.

We advise the applicant that, in addition to planning permission, it is their responsibility to ensure they secure all other permits/consents/licences relevant to their development. Please refer to our [website](#) for further details.

If you have any queries on the above, please do not hesitate to contact us.

Yn gywir / Yours faithfully

Pauline Gallagher Brown

Cynghorydd - Cynllunio Datblygu / Advisor - Development Planning

Ffôn/Tel: 0300 065 4086

E-bost/E-mail: northplanning@cyfoethnaturiolcymru.gov.uk

Croesewir gohebiaeth yn Gymraeg a byddwn yn ymateb yn Gymraeg, heb i hynny arwain at oedi. / Correspondence in Welsh is welcomed, and we will respond in Welsh without it leading to a delay.