

DOOR SCHEDULE - TYPE Fa					ALL GLAZING BETWEEN FF1 AND ROOM IN WALLS AND PARTITIONS AND BETWEEN FF1 AND 150MM R/A DOOR OR IN A SIDE PANEL CLOSE TO EITHER EDGE OF THE DOOR SHALL BE LAMINATED (NOT TOUCHENED) GLASS AS DEFINED IN BR08-181. SAFETY GLAZING TO BE PERMANENTLY MARKED TO COMPLY WITH BS 6206:181.		WALL TYPES	
REF	TYPE	HEIGHT	WIDTH	COMMENTS				
WINDOW SCHEDULE - TYPE Fa								
REF	TYPE	WIDTH	HEIGHT	COMMENTS				
00 - GROUND FLOOR								
D4	INT SINGLE	2110	836					
D5	INT SINGLE	2110	836					
D6	INT SINGLE	2110	760					
D7	INT SINGLE	2110	836					
D8	INT SINGLE	2110	836					
D9	INT SINGLE	2110	912					
XD1	ExtSGL IG X0K3	2110	1023					
XD2	EXT SINGLE GLAZED	2110	1023					
XD3	DoorEndGlazed with reveals	2110	1585					
01 - FIRST FLOOR								
D10	INT SINGLE	2110	836					
D11	INT SINGLE	2110	760					
D12	INT SINGLE	2110	836					
D13	INT SINGLE	2110	836					
D14	INT SINGLE	2110	836					
D15	INT SINGLE	2110	836					
D16	INT SINGLE	2110	836					
D17	INT SINGLE	2110	836					
01 - FIRST FLOOR								
W9	1247.5 x 1211	1248	1210					
W10	1247.5 x 1211	1248	1210					
W11	685 x 1210 - Brck	685	1210					
W12	1810 x 1210	1810	1210					
W13	460 x 1060	460	1060					
W14	460 x 1060	460	1060					
W15	460 x 1060	460	1060					
W16	1247.5 x 1211	1248	1210					
NOTE: BACKGROUND VENTILATION TO BE 8000 SQ MM TO HABITABLE ROOMS, 4000 SQMM TO BATHROOMS AND UTILITIES, WHICH IS TO BE PROVIDED BY THE WINDOW AND EXTERNAL DOOR TRICKLE VENTS. GROUND FLOOR DOORS TO HABITABLE ROOMS AND ROOMS CONTAINING A WC TO HAVE A MINIMUM CLEAR OPENING OF 800MM WHEN NOT APPROACHED HEAD ON AND 750MM FINISHED GAP AT THE BOTTOM TO PROVIDE REQUIRED BACKGROUND VENTILATION (PROVIDE A 20MM UNFINISHED GAP WHERE FINISHES ARE NOT Laid). ALL CYLINDER DOORS TO BE VENTED EQUIVALENT TO 600MM2.								
DOOR SCHEDULE - TYPE Fa					WALL TYPES			
REF	TYPE	HEIGHT	WIDTH	COMMENTS				
EXTERNAL WALL								
BRICK OR RENDER ON LAY-LITE BLOCK OUTER LEAF, 125MM CAVITY FILLED WITH SUPABEAD INSULATION (K=0.031), 100MM THERMAULITE TURBO BLOCK, PLASTERBOARD ON DABS, U-VALUE = 0.20 W/M²K. IF USING THERMAULITE TN BLOCK THEN U-VALUE IS 0.21 W/M²K.					253			
					377			
					312			
					150			
					105			
PARTIAL WALL								
125MM FILLED/CLEAR CAVITY WITH EACH SIDE 100MM BLOCKWORK & 12.5MM PLASTERBOARD ON DABS WITH SKIM FINISH								
INTERNAL LOADBEARING WALL (REFER TO ENGINEERS DETAILS)								
100MM BLOCKWORK & 12.5MM PLASTERBOARD ON DABS WITH SKIM FINISH TO BOTH SIDES								
INTERNAL NON-LOADBEARING WALL								
TIMBER STUDS (75X88 @ 600CTRS INDICATED) - 75MM GYPSUM ACUSTIC PARTITION ROLL (ONLY WHERE INDICATED) - WALL FINISHED BOTH SIDES WITH 12.5MM LAYERS OF 12.5MM PLASTERBOARD AND SKIM FINISH UNLESS TILED.								

