



MEMORANDUM

From: Ian Jones
**Head of Service Public Protection
Economy and Planning**

To: David Fitzsimon
Chief Officer

Our Ref:

Your Ref: P/2022/0777

Date: 28-10-2022

Town and Country Planning Act 1990

Town and Country Planning (General Development Procedure) Order 1996

Re: P/2022/0777, 30 TOWN HILL WREXHAM

NEWID DEFNYDD ADEILAD O DDOSBARTH A1 (MANWERTHU) I DDOSBARTH A3 (BWYD A DIOD). / CHANGE OF USE OF BUILDING FROM CLASS A1 (RETAIL) TO CLASS A3 (FOOD AND DRINK)

ZP16 -GREASE TRAPS

Prior to first use of the development a suitable grease trap shall be provided in order to prevent entry into the public sewerage system of matter (cooking fats, oils and grease etc) likely to interfere with the free flow of the sewer contents, or which would prejudicially affect the treatment and disposal of such contents.

ZP05 - NOISE GENERATION - BS4142 REQUIRED

The rating level of any noise generated by reason of this development, to include air handling plant, shall not exceed the pre-existing background level at any time. The noise levels shall be determined at nearby noise sensitive premises, and measurements and assessment shall be made in accordance with BS4142:2014 Methods for rating and assessing industrial and commercial sound.

ZP03 - (ODOUR) KITCHEN EXTRACTION DETAILS REQUIRED

No part of the development shall commence until details of the means of ventilation for the extraction and dispersal of cooking smells, including details of its method of construction, odour control measures, its appearance and finish have been submitted to

and approved in writing by the Local Planning Authority. The approved details shall be fully implemented prior to first use of the development and shall thereafter be permanently retained in an effective condition.

When designing such a system, it is recommended that reference to the following guidance should be made: EMAQ Control of Odour and Noise from Commercial Kitchen Exhaust Systems (Update to the 2004 report prepared by NETCEN for DEFRA).

A32N - FOOD PREMISES – FOG ADVICE

Guidance on best management practice for catering outlet for the dispersal of fats, oils, grease and food waste, as issued by Water UK is available by contacting the Council's Planning & Regulatory Department on 01978 292 040 for further advice and information.

F04N - FOOD HYGIENE REGULATIONS

You are advised that the premises should comply with the relevant Food Hygiene Legislation, and you are advised to contact Council's Planning & Regulatory Department on 01978 298 989 for further advice and information.

.....

Head of Service Public Protection