

Maes Y Ffynnon,
Penrhosgarnedd,
Bangor,
Gwynedd
LL572DW

Wrexham County Borough Council,
The Guildhall,
Wrexham,
LL11 1AY

ebost/email:
northplanning@cyfoethnaturiolcymru.gov.uk

10/10/2022

Dear Sir/Madam,

PROPOSAL: ERECTION OF 3 DWELLINGS

LOCATION: WOODVILLE GARAGE, GRESFORD ROAD, LLAY, WREXHAM, LL12 0NW

Thank you for re-consulting Cyfoeth Naturiol Cymru / Natural Resources Wales about the above with additional information, which we received on 30th September 2022.

We continue to have concerns with the application as submitted because inadequate information has been provided in support of the proposal. To overcome these concerns, you should seek further information from the applicant regarding protected sites. If this information is not provided, we would object to this planning application. Further details are provided below.

Protected Sites

We note the application site is within the catchment of the River Dee and Bala Lake Special Area of Conservation (SAC). As you are aware, on the 21st January 2021, we published an evidence package outlining phosphorus levels for all river SACs across Wales. In line with our [Planning Advice](#) (July 2022), under the Habitats Regulations, Planning Authorities must consider the phosphorus impact of proposed developments on water quality within SAC river catchments. We therefore advise you to consider whether the proposals, as submitted, would increase the volume of foul discharge from the site in planning terms.

We note from the information submitted that the development has the potential to increase the amount of phosphorus being discharged from the site. As such, we refer you to our Planning Advice and advise you to seek further information from the applicant. We advise you to seek further information as identified in the section titled 'What does this mean for development proposals involving connection to public wastewater treatment works'.

We note from the amended drainage plans that it is the intention connect to a package treatment plant with a phosphorus reduction kit prior to discharging into the main foul sewer. Please note that chemical pre-treatment to reduce phosphorus in wastewater discharging to a public sewer may adversely affect the hydraulic and biological performance of the wider

sewer system and treatment works. In the first instance Planning Authorities / developers should seek advice from the water company for any such proposals.

Provided this advice is followed and you are able to conclude that the development is not likely to have a significant effect on the SAC, we would have no objection to the proposal. However, should you conclude that the proposed development is likely to have a significant effect on the SAC, please consult us on your Appropriate Assessment under Regulation 63 of the Conservation of Habitats and Species Regulations 2017 (as amended).

Contamination

We concur with the Contaminated Land Conditions recommended by Angela Guy, Contaminated Land Officer, Wrexham County Borough, in her letter dated 19th May 2022.

Other Matters

Our comments above only relate specifically to matters included on our checklist, *Development Planning Advisory Service: Consultation Topics* (September 2018), which is published on our [website](#). We have not considered potential effects on other matters and do not rule out the potential for the proposed development to affect other interests.

We advise the applicant that, in addition to planning permission, it is their responsibility to ensure they secure all other permits/consents/licences relevant to their development. Please refer to our [website](#) for further details.

If you have any queries on the above, please do not hesitate to contact us.

Yours faithfully

Ruth Prichard

Cynghorydd - Cynllunio Datblygu / Advisor - Development Planning
Cyfoeth Naturiol Cymru / Natural Resources Wales