

Maes Y Ffynnon,
Penrhosgarnedd,
Bangor,
Gwynedd
LL572DW

Wrexham County Borough Council,
The Guildhall,
Wrexham,
LL11 1AY

ebost/email:
northplanning@cyfoethnaturiolcymru.gov.uk

28/02/2023

Dear Sir/Madam,

PROPOSAL: DISCHARGE OF CONDITION 5 (DRAINAGE) OF PLANNING PERMISSION P/2022/0476

LOCATION: PLAS EYTON, EYTON, WREXHAM, LL13 0YD

Thank you for consulting Cyfoeth Naturiol Cymru / Natural Resources Wales about the above, which we received on 14th February 2023.

We have no objection to the partial discharge of condition 5 (foul drainage) for the above proposal.

Foul Drainage

We note the application site is within the catchment of the River Dee and Bala Lake Special Area of Conservation (SAC). As you are aware, on the 21st January 2021, we published an evidence package outlining phosphorus levels for all river SACs across Wales. In line with our [Planning Advice](#) (July 2022), under the Habitats Regulations, Planning Authorities must consider the phosphorus impact of proposed developments on water quality within SAC river catchments. We therefore advise you to consider whether the proposals, as submitted, would increase the volume of foul discharge from the site in planning terms.

However, recognising the specific nature of the application submitted e.g. private sewage treatment system which meets the screening criteria set out in our Planning Advice, we are satisfied that it is unlikely to increase the amount of phosphorus entering the catchment. Therefore, we are satisfied that the proposal is not likely to have a significant effect on the River Dee and Bala Lake SAC

The developer/applicant should ensure that the existing septic tank has sufficient capacity to accommodate any increase in flows from the proposed development.

Applicants wishing to operate a private sewerage system will need either to apply to us for an environmental permit or register with us for an exemption from the permit requirement. Septic tanks and small sewage treatment works that meet certain criteria may be registered as exempt.

A step by step guide to registering an exemption can be found on our [website](#).

If the septic tank or private sewage treatment system is not eligible for an exemption, the Applicant will need to apply for an environmental permit, further details can be found [here](#). Should a permit be required further information may be needed as part of that application process. The Applicant is therefore advised to contact us for pre-application advice at the earliest opportunity to try to ensure that there is no conflict between any planning permission granted and the permit requirements. Further details on how to access our pre-application advice service can be found [here](#).

It is important to note that a grant of planning permission does not guarantee that a permit will be granted. A proposal may be deemed unacceptable either because of environmental risk or because upon further investigation, a connection to mains sewer was feasible. Applicants are encouraged to ensure they have all the required permissions, consents, permits and any other approvals in place prior to commencement of works on the site.

Where private sewage treatment/disposal facilities are utilised, they must be installed and maintained in accordance with British Standard 6297 and Approved Document H of the Building Regulations. We also refer the Applicant to Guidance for Pollution Prevention 4 on the NetRegs [website](#), which provides further information.

Surface Water Drainage

We have no observations to make on the discharge of this part of condition 5

Other Matters

Our comments above only relate specifically to matters included on our checklist, *Development Planning Advisory Service: Consultation Topics* (September 2018), which is published on our [website](#). We have not considered potential effects on other matters and do not rule out the potential for the proposed development to affect other interests.

We advise the applicant that, in addition to planning permission, it is their responsibility to ensure they secure all other permits/consents/licences relevant to their development. Please refer to our [website](#) for further details.

If you have any queries on the above, please do not hesitate to contact us.

Yours faithfully

Ruth Prichard

Cynghorydd - Cynllunio Datblygu / Advisor - Development Planning
Cyfoeth Naturiol Cymru / Natural Resources Wales