



**Cyfoeth
Naturiol
Cymru
Natural
Resources
Wales**

Ein cyf/Our ref: CAS-204382-L9V2
Eich cyf/Your ref: P/2022/0992

Maes Y Ffynnon,
Penrhosgarnedd,
Bangor,
Gwynedd
LL572DW

Wrexham County Borough Council,
The Guildhall,
Wrexham,
LL11 1AY

ebost/email:
northplanning@cyfoethnaturiolcymru.gov.uk

14/12/2022

Annwyl Syr/Madam / Dear Sir/Madam,

BWRIAD / PROPOSAL: CHANGE OF USE OF DOMESTIC GARAGE TO DOG DAY CARE BUILDING

LLEOLIAD / LOCATION: 17, RHOS BERSE ROAD, COEDPOETH, WREXHAM, LL11 3BT

Thank you for consulting Cyfoeth Naturiol Cymru / Natural Resources Wales about the above, which we received on 29/11/2022.

We have no objection to the proposed development as submitted and provide the following advice.

Foul Drainage and Protected Sites

We note the application site is within the catchment of the River Dee and Bala Lake Special Area of Conservation (SAC). As you are aware, on the 21st January 2021, we published an evidence package outlining phosphorus levels for all river SACs across Wales. In line with our [Planning Advice](#) (July 2022), under the Habitats Regulations, Planning Authorities must consider the phosphorus impact of proposed developments on water quality within SAC river catchments.

Based on the information provided, and confirmation from the Local Planning Authority that the proposal will not result in an increase in foul drainage due to activities relating to the care of the dogs, the application as submitted is unlikely to increase the amount of phosphorus entering the catchment. Therefore, we are satisfied that the proposal is not likely to have a significant effect on the River Dee and Bala Lake SAC.

The applicant should ensure that the existing septic tank has sufficient capacity to accommodate any increase in flows from the proposed development.

Applicants wishing to operate a private sewerage system will need either to apply to us for an environmental permit or register with us for an exemption from the permit requirement. Septic tanks and small sewage treatment works that meet certain criteria may be registered as exempt.

A step by step guide to registering an exemption can be found on our [website](#).

If the septic tank or private sewage treatment system is not eligible for an exemption, the Applicant will need to apply for an environmental permit, further details can be found [here](#). Should a permit be required further information may be needed as part of that application process. The Applicant is therefore advised to contact us for pre-application advice at the earliest opportunity to try to ensure that there is no conflict between any planning permission granted and the permit requirements. Further details on how to access our pre-application advice service can be found [here](#).

It is important to note that a grant of planning permission does not guarantee that a permit will be granted. A proposal may be deemed unacceptable either because of environmental risk or because upon further investigation, a connection to mains sewer was feasible. Applicants are encouraged to ensure they have all the required permissions, consents, permits and any other approvals in place prior to commencement of works on the site.

Where private sewage treatment/disposal facilities are utilised, they must be installed and maintained in accordance with British Standard 6297 and Approved Document H of the Building Regulations. We also refer the Applicant to Guidance for Pollution Prevention 4 on the NetRegs [website](#), which provides further information.

Other Matters

Our comments above only relate specifically to matters included on our checklist, *Development Planning Advisory Service: Consultation Topics* (September 2018), which is published on our [website](#). We have not considered potential effects on other matters and do not rule out the potential for the proposed development to affect other interests.

We advise the applicant that, in addition to planning permission, it is their responsibility to ensure they secure all other permits/consents/licences relevant to their development. Please refer to our [website](#) for further details.

If you have any queries on the above, please do not hesitate to contact us.

Yn gywir / Yours faithfully,

Pauline Gallagher Brown

Cynghorydd - Cynllunio Datblygu / Advisor - Development Planning
Cyfoeth Naturiol Cymru / Natural Resources Wales