

Maes Y Ffynnon,  
Penrhosgarnedd,  
Bangor,  
Gwynedd  
LL572DW

Wrexham County Borough Council,  
The Guildhall,  
Wrexham,  
LL11 1AY

ebost/email:  
northplanning@cyfoethnaturiolcymru.gov.uk

18/05/2022

Dear Sir/Madam,

**BWRIAD / PROPOSAL: CARAFAN BRESWYL (YN OL DREMIOL) /RESIDENTIAL CARAVAN (IN RETROSPECT)**

**LLEOLIAD / LOCATION: PENYLLAN FARM, WREXHAM ROAD, MARCHWIEL, WREXHAM**

Thank you for consulting Cyfoeth Naturiol Cymru / Natural Resources Wales about the above, which we received on 02/02/2021

**We have concerns with the application as submitted because inadequate information has been provided in support of the proposal. To overcome these concerns, you should seek further information from the applicant regarding protected sites and foul drainage. If this information is not provided, we would object to this planning application. Further details are provided below.**

We note the application site is within the catchment of the River Dee and Bala Lake Special Area of Conservation (SAC). As you are aware, on the 21<sup>st</sup> January 2021, we published an evidence package outlining phosphorus levels for all river SACs across Wales. As part of this package, we issued a [Planning Position Statement](#), in which we advised that any proposed development that might increase the amount of phosphate (or phosphorus) within a river SAC catchment could lead to damaging effects to the SAC. Therefore, such proposals should be screened through a Habitats Regulations Assessment (HRA), to determine whether they are likely to have a significant effect on the SAC. We have also issued [Planning Advice](#) (May 2021) which gives specific advice in respect of foul drainage arrangements for new developments.

We note that foul water disposal is proposed via a connection to an existing septic tank, rather than connecting to the public sewer. However, as you are aware, the site is within a sewered area.

The installation of private sewage treatment facilities within publicly sewered areas is not normally considered environmentally acceptable because of the greater risk of failures leading to pollution of the water environment compared to public sewerage systems.

Section 6.6.21 of Planning Policy Wales states 'Any development discharging domestic sewage should connect to the foul sewer where it is reasonable to do so. Development proposing the use of non-mains drainage schemes will only be considered acceptable where connection to the main sewer is not feasible...'

Welsh Government Circular 008/2018 on the use of private sewerage in new development, specifically paragraphs 2.3-2.5, stresses the first presumption must be to provide a system of foul drainage discharging into a public sewer. Only where having taken into account the cost and/or practicability it can be shown to the satisfaction of the local planning authority that connection to a public sewer is not feasible, should non-mains foul sewage disposal solutions be considered.

The Applicant should also be aware that in order to operate a private drainage system, they would need to apply for an environmental permit or register an exemption with us. We will not normally grant a discharge permit for a private sewage treatment system where it is reasonable to connect to the public foul sewer.

We therefore require the Applicant to either amend their proposals to ensure that the foul drainage is connected to the mains sewerage system or provide detailed evidence to demonstrate that it is not reasonable to connect.

The Applicant should thoroughly investigate the possibility of connecting to the foul sewer by taking the following steps:

- Formally approach the sewerage undertaker regarding a connection under Section 106 or a requisition under Section 98 of the Water Industry Act (WIA) 1991.
- Serve notice for connection under Section 106 of the WIA 1991 if the sewerage undertaker has refused connection.
- Provide details of the reasons given by the sewerage undertaker if it has refused connection under section 98 or section 106 of the WIA 1991 and confirmation that they have appealed against this decision.
- Demonstrate that it is not reasonable to connect to the public foul sewer.
- Where it is not reasonable to connect to the public foul sewer, demonstrate that they have considered requesting that the sewerage undertaker adopt their proposed system.

The Applicant should be aware that should a connection to the mains sewer not be feasible, they will also need to demonstrate that the proposal would not pose an unacceptable risk to the water environment. Welsh Government Circular 008/2018 advises that a full and detailed consideration be given to the environmental criteria listed under paragraph 2.6 of the Circular, in order to justify the use of private sewerage.

## **Other Matters**

Our comments above only relate specifically to matters included on our checklist, *Development Planning Advisory Service: Consultation Topics* (September 2018), which is published on our [website](#). We have not considered potential effects on other matters and do not rule out the potential for the proposed development to affect other interests.

We advise the applicant that, in addition to planning permission, it is their responsibility to ensure they secure all other permits/consents/licences relevant to their development. Please refer to our [website](#) for further details.

If you have any queries on the above, please do not hesitate to contact us.

Yn gywir / Yours faithfully

**Rhys Jones**

Cynghorydd - Cynllunio Datblygu / Advisor - Development Planning  
Cyfoeth Naturiol Cymru / Natural Resources Wales