



0 1 2 3 4 5 10

GRAPHIC SCALE: 1:100

A		B		C		D	
E1		E2		F1	30min fire rated	F2	60min fire rated

1. All signs to be screw fixed rigid plastic.
2. Fire Extinguishers to be supplied by employer and fitted by the Contractor to the recommendations made by the property Fire Risk Officer.
3. Final signage to the property Fire Risk Officers recommendations.
4. Refer to Services Engineer's drawing for details and locations of illuminated signs, emergency lighting and fire/smoke detection/ alarm.
5. Fire alarm system to have visual and audible alarm to BS 5839. Refer to Services Engineer's drawing for details
6. Emergency lighting to be provided throughout on separate circuits to general lighting to BS 5266. Refer to Services Engineer's drawing for details
7. Surface spread of flame to escape routes corridors and ceilings to be Class 0.
8. Where signs B, C and D is to be used include to both sides at eye level and to both leaves of double doors.
9. Where sign E1 is to be used, these are to be wall mounted and point towards route of closest exit.
10. Where sign E2 is to be used, these are to be ceiling mounted and point towards route of closest exit.
11. Include Unisex & Disabled pictograms to Shower & W/Cs

Fire Suppression System: Water mist system as MEP Engineer's Specification

P3	Stage 4 Development	24/05/2022
P2	Trader kitchen retained	01/04/2022
P1	Updated Stage 3 Issue following client comments	31/01/2022
P0	Updated Stage 3 Issue CB CB CB	14/12/2021
REV	DESCRIPTION DRAWN BY CHECKED BY APPROVED BY	DATE
RIBA PLAN OF WORK 2013 WORKSTAGE		LEVEL OF MODEL DEFINITION (LoD)
Stage 3 - Spatial Coordination		LoD 2 - Conceptual Model
PURPOSE OF ISSUE - SUITABLE FOR ...		BS1192 STATUS
Information		Status S2 - Information



CLIENT
WCBC

PROJECT TITLE
Wrexham Butchers Market

DRAWING TITLE
Proposed Ground Floor Fire Plan

PROJECT No 19556	SCALE @ A1 As indicated	
DRAWING No S51192.007 A-221018 S5 EN ISO1665	1150: Project - Originator - Volume - Level - Type - Rate - Number 19552: Project - Originator - Functional - Spatial - Form - Discipline - Number Breakdown Breakdown	REVISION
WBM-LAW-X-G00-DR-	A-051001	P3
DO NOT SCALE	Any discrepancy or query concerning this drawing should be referred to the Architect Copyright © LAWRY LIMITED	
Registered Office: Greenmeadow Springs, 1 Cae Gyfory, Tynnyrall, CARDIFF CF15 7AB Reg. Co. No. 272478, VAT Reg. No. 138 646 060		