

**MEMORANDUM**

From: Rebecca Pomeroy**To: Shawn Fleet****Head of Service Public Protection
Planning Control Manager****Our Ref:****Your Ref: P/2022/0635****Date: 22-08-2022**

Town and Country Planning Act 1990**Town and Country Planning (General Development Procedure) Order 1996****Re: P/2022/0635, 16 REDWITHER INDUSTRIAL COMPLEX WREXHAM INDUSTRIAL ESTATE
WREXHAM****NEWID DEFNYDD O B1 (SWYDDFA) I D1 (GOFAL IECHYD) / CHANGE OF USE FROM B1 (OFFICE)
TO D1 (HEALTHCARE)****ZIP04 - AIR HANDLING / EXTRACTION PLANT BS4142 ASSESSMENT**

If the proposed activity includes the use of any air handling plant I recommend the inclusion of the following condition:

The rating level of any noise generated by air handling plant associated with the development shall not exceed the pre-existing background level at any time. The noise levels shall be determined at nearby noise sensitive premises, and measurements and assessment shall be made in accordance with BS4142:2014 Methods for rating and assessing industrial and commercial sound.

.....
Interim Chief Officer Planning and Regulatory

