

Wrexham County Borough Council
16, Lord Street
Wrexham
LL11 1LG

Date: 07/12/2021
Our Ref: PLA0061594
Your Ref: P/2021/1104

Dear Sir/Madam,

Site: Halton Farm lane from ponty y Blew, Halton, Wrexham.
Development: Erection of covered holding yard and all associated works

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

Welsh Water have no objection to proposed development.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at developer.services@dwrcymru.com

Please quote our reference number in all communications and correspondence.

Yours faithfully,

Rhodri Perry
Development Control Officer
Developer Services