

Maes Y Ffynnon,
Penrhosgarnedd,
Bangor,
Gwynedd
LL572DW

Wrexham County Borough Council,
The Guildhall,
Wrexham,
LL11 1AY

ebost/email:
northplanning@cyfoethnaturiolcymru.gov.uk

09/06/2022

Annwyl Syr/Madam / Dear Sir/Madam,

**BWRIAD / PROPOSAL: OUTLINE APPLICATION FOR ERECTION OF 33 DWELLINGS
(APPEARANCE, LANDSCAPING, LAYOUT AND SCALE RESERVED)
LLEOLIAD / LOCATION: LAND OFF BETHANIA ROAD, ACREFAIR, WREXHAM (Major)**

Thank you for consulting Cyfoeth Naturiol Cymru / Natural Resources Wales about the above, which we received on 23/05/2022.

We have concerns with the application as submitted because inadequate information has been provided in support of the proposal. To overcome these concerns, further consideration is required regarding foul drainage. Further details are provided below.

We also advise that based on the information submitted to date, conditions regarding contaminated land should be attached to any planning permission granted and the document identified below (protected species section) should be included in the approved plans and documents condition on the decision notice. Without the inclusion of these conditions and document, we would object to this planning application.

Foul Drainage

We note the application site is within the catchment of the River Dee and Bala Lake Special Area of Conservation (SAC). As you are aware, on the 21st of January 2021, we published an evidence package outlining phosphate levels for all river SACs across Wales. As part of this package, we issued a [Planning Position Statement](#), in which we advised that any proposed development that might increase the amount of phosphate within a river SAC catchment could lead to damaging effects to the SAC. Therefore, such proposals should be screened through a Habitats Regulations Assessment (HRA), to determine whether they are likely to have a significant effect on the SAC. We have also issued [Planning Advice](#) (May

2021) which gives specific advice in respect of foul drainage arrangements for new developments.

We note from the information submitted that the development has the potential to increase the volume or concentration of wastewater and associated phosphate levels being discharged from the site via mains sewer connection. However, we note that a submitted letter from Welsh Water dated 01/06/2022 confirms that the development site would drain to Cefn Mawr wastewater treatment works, which has capacity to treat the additional wastewater and phosphorus from the proposed development within the existing discharge permit limits.

As per our [Planning Advice](#), development connecting to an existing public wastewater treatment works that has the capacity and associated phosphorus stripping facility to accommodate additional wastewater is unlikely to increase phosphorus inputs to a SAC beyond what has already been assessed and permitted by NRW. However, your authority, should examine the appropriate assessments carried out in respect of the extant environmental permit(s), along with any new information or changes in circumstances, to ensure that adverse effect on site integrity can be ruled out. Should you need to obtain a copy of the relevant appropriate assessment, please contact us.

Ultimately, the suitability of foul drainage arrangements for the proposed development is a matter for your Authority to determine.

Should your Authority conclude that the proposal is likely to have a significant effect on the River Dee and Bala Lake SAC, please consult us on your appropriate assessment under Regulation 63 of the Conservation of Habitats and Species Regulations 2017 (as amended).

Land Contamination

We note that the development lies within the former Air Products Social Club landfill site, and therefore has the potential for contamination. Based on the application as submitted, we would advise that the conditions below are attached to any planning permission in order to protect controlled waters.

Land affected by contamination

Condition 1: No development or phase of development, shall commence until the following components of a scheme to deal with the risks associated with contamination at the site, have been submitted to and approved in writing by the Local Planning Authority.

1. A preliminary risk assessment which has identified:

- all previous uses
- potential contaminants associated with those uses
- a conceptual model of the site indicating sources, pathways and receptors
- potentially unacceptable risks arising from contamination at the site

2. A site investigation scheme, based on (1) to provide information for a detailed assessment of the risk to all receptors that may be affected, including those off site.

3. The results of the site investigation and the detailed risk assessment referred to in (2) and, based on these, an options appraisal and remediation strategy giving full details of the remediation measures required and how they are to be undertaken.

4. A verification plan providing details of the data that will be collected in order to demonstrate that the works set out in the remediation strategy in (3) are complete and identifying any requirements for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action.

The remediation strategy and its relevant components shall be carried out in accordance with the approved details.

Justification: To ensure the risks associated with contamination at the site have been fully considered prior to commencement of development as controlled waters are of high environmental sensitivity; and where necessary remediation measures and long-term monitoring are implemented to prevent unacceptable risks from contamination.

Contamination verification report

Condition 2: Prior to the occupation of the development, a verification report demonstrating completion of works set out in the approved remediation strategy and the effectiveness of the remediation shall be submitted to, and approved in writing by the Local Planning Authority. The report shall include results of sampling and monitoring carried out in accordance with the approved verification plan to demonstrate that the site remediation criteria have been met. It shall also include a long-term monitoring and maintenance plan for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action, as identified in the verification plan. The long-term monitoring and maintenance plan shall be carried out in accordance with the approved details.

Justification: To ensure the methods identified in the verification plan have been implemented and completed and the risk associated with the contamination at the site has been remediated prior to occupation or operation, to prevent both future users of the land and neighbouring land are minimised, together with those to controlled waters, property and ecological systems, and to ensure that the development can be carried out safely without unacceptable risks to workers, neighbours and other offsite receptors.

Unsuspected contamination

Condition 3: If, during development, contamination not previously identified is found to be present at the site then no further development (unless otherwise agreed in writing with the Local Planning Authority) shall be carried out until a remediation strategy detailing how this unsuspected contamination shall be dealt with has been submitted to and approved in writing by the Local Planning Authority. The remediation strategy shall be carried out as approved.

Justification: To ensure the risks associated with previously unsuspected contamination at the site are dealt with through a remediation strategy, to minimise the risk to both future users of the land and neighbouring land, and to ensure that the development can be carried out safely without unacceptable risks. A site investigation may not uncover all instances of contamination and this condition ensures that contamination encountered during the development phase is dealt with appropriately.

Piling

Condition 4: No development shall commence until details of piling or any other foundation designs using penetrative methods sufficient to demonstrate that there is no unacceptable risk to groundwater have been submitted to and approved in writing by the Local Planning Authority. The piling/foundation designs shall be implemented in accordance with the approved details.

Justification: Piling/foundation details should be submitted to ensure there is no unacceptable risk to groundwater during construction and methods/design are agreed prior to the commencement of development or phase of development.

Surface water drainage

Condition 4: No infiltration of surface water drainage into the ground is permitted other than with the express written consent of the local planning authority, which may be given for those parts of the site where it has been demonstrated that there is no resultant unacceptable risk to controlled waters. The development shall be carried out in accordance with the approval details.

Justification: To prevent both new and existing development from contributing to or being put at unacceptable risk from or being adversely affected by unacceptable levels of water pollution.

Protected Species

Bats

We note that the ecological report submitted in support of the above application (Land off Bethania Road, Acrefair Protected Species Walkover Survey. Steven Whitcher 04/08/2022) has identified that Bats may present at the application site. From the information submitted, we consider that the proposed development represents a lower risk for bats, as defined in our guidance document '*Natural Resources Wales Approach to Bats and Planning (2015)*'. Bats and their breeding and resting places are protected under the Conservation of Habitats and Species Regulations 2017.

As this is a lower risk case for bats, we consider that the development is not likely to be detrimental to the maintenance of the population of the species concerned at a favourable conservation status in its natural range.

Furthermore, we advise that the proposed development is not likely to harm or disturb the bats or their breeding sites and resting places at this site, provided the avoidance measures described in the bat report are implemented.

The report must be included in the 'approved list of plans / documents' condition within the decision notice should consent for the project be granted.

Please consult us again if any further information shows that this is no longer a lower risk case.

Great Crested Newts (GCN)

We note that the ecological report submitted in support of the above application (Land off Bethania Road, Acrefair, Protected Species Walkover Survey. Steven Whitcher 04/08/2022) has identified that GCN may be present at the application site. GCN and their breeding and resting places are protected under the Conservation of Habitats and Species Regulations 2017.

We consider that the development is not likely to be detrimental to the maintenance of the population of the species concerned at a favourable conservation status in its natural range.

Furthermore, we advise that the proposed development is not likely to harm or disturb GCN or their breeding sites and resting places at this site, provided the avoidance measures described in the ecological report are implemented.

The report must be included in the 'approved list of plans / documents' condition within the decision notice should consent for the project be granted.

Please consult us again if any further information shows that this is no longer a lower risk case.

Other Matters

Our comments above only relate specifically to matters included on our checklist, *Development Planning Advisory Service: Consultation Topics* (September 2018), which is published on our [website](#). We have not considered potential effects on other matters and do not rule out the potential for the proposed development to affect other interests.

We advise the applicant that, in addition to planning permission, it is their responsibility to ensure they secure all other permits/consents/licences relevant to their development. Please refer to our [website](#) for further details.

If you have any queries on the above, please do not hesitate to contact us.

Yn gywir / Yours faithfully

Rhys Jones

Cynghorydd - Cynllunio Datblygu / Advisor - Development Planning

Cyfoeth Naturiol Cymru / Natural Resources Wales