

Wrexham County Borough Council
16, Lord Street
Wrexham
LL11 1LG

Date: 08/03/2022
Our Ref: PLA0064003
Your Ref: P 2022 0200

Dear Sir/Madam,

Grid Ref: SJ324563 332487 356379

Site: P R Pugh Miners Road Llay

Development: Variation Of Conditions 2 And 9 Of Planning Permission P/2018/0797 To Amend Site Layout.

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

ASSET PROTECTION

The proposed development site is crossed by a 150mm diameter foul rising main sewer and a 225mm foul gravity public sewer with their approximate positions being marked on the attached Statutory Public Sewer Record. Under Section 159 of the Water Industry Act 1991, Dwr Cymru Welsh Water has rights of access to its apparatus at all times, and as such would require an easement of 3m either side of the centreline of this pipes. Should the proposed development be located within the protection zones of the sewers crossings, there would be a requirement to divert the public sewers, which can be applied for under Section 185 of the Water Industry Act 1991.

SEWERAGE

Having assessed the proposal, we note that no foul flows are to be generated as part of the proposed development and that surface water runoff will be discharged into a soakaway system. Dwr Cymru Welsh Water consider these drainage arrangements to be acceptable in principle. Nonetheless, for the avoidance of doubt, we would kindly request that if you are minded to grant Planning Consent for the above development that the Condition and Advisory Notes provided below are included within the consent to ensure no detriment to existing residents or the environment and to Dwr Cymru Welsh Water's assets.

Condition

No surface water and/or land drainage shall be allowed to connect directly or indirectly with the public sewerage network

Reason: To prevent hydraulic overloading of the public sewerage system, to protect the health and safety of existing residents and ensure no pollution of or detriment to the environment

Advisory Notes

The applicant may need to apply to Dwr Cymru / Welsh Water for any connection to the public sewer under S106 of the Water Industry Act 1991. If the connection to the public sewer network is either via a lateral drain (i.e. a drain which extends beyond the connecting property boundary) or via a new sewer (i.e. serves more than one property), it is now a mandatory requirement to first enter into a Section 104 Adoption Agreement (Water Industry Act 1991). The design of the sewers and lateral drains must also conform to the Welsh Ministers Standards for Gravity Foul Sewers and Lateral Drains, and conform with the publication "Sewers for Adoption"- 7th Edition. Further information can be obtained via the Developer Services pages of www.dwrcymru.com.

The applicant is also advised that some public sewers and lateral drains may not be recorded on our maps of public sewers because they were originally privately owned and were transferred into public ownership by nature of the Water Industry (Schemes for Adoption of Private Sewers) Regulations 2011. The presence of such assets may affect the proposal. In order to assist us in dealing with the proposal the applicant may contact Dwr Cymru Welsh Water. Under the Water Industry Act 1991 Dwr Cymru Welsh Water has rights of access to its apparatus at all times.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at developer.services@dwrcymru.com

Please quote our reference number in all communications and correspondence.

Yours faithfully,

Jake MacMillan
Development Control Officer
Developer Services



Welsh Water is owned by Glas Cymru – a 'not-for-profit' company.
Mae Dŵr Cymru yn eiddo i Glas Cymru – cwmni 'nid-er-elw'.

We welcome correspondence in
Welsh and English

Dŵr Cymru Cyf, a limited company registered in
Wales no 2366777. Registered office: Pentwyn Road,
Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y
Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng
Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn
Nelson, Treharris, Morgannwg Ganol CF46 6LY.



Welsh Water is owned by Glas Cymru – a ‘not-for-profit’ company.
Mae Dŵr Cymru yn eiddo i Glas Cymru – cwmni ‘nid-er-elw’.

We welcome correspondence in
Welsh and English

Dŵr Cymru Cyf, a limited company registered in
Wales no 2366777. Registered office: Pentwyn Road,
Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y
Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng
Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn
Nelson, Treharris, Morgannwg Ganol CF46 6LY.