

Maes Y Ffynnon,
Penrhosgarnedd,
Bangor,
Gwynedd
LL572DW

Wrexham County Borough Council,
The Guildhall,
Wrexham,
LL11 1AY

ebost/email:
northplanning@cyfoethnaturiolcymru.gov.uk

19/10/2021

Dear Sir/Madam,

**BWRIAD / PROPOSAL: ADEILADU STORFA SLYRI A THO ARNI A GWAITH
CYSYLLTIEDIG / ERECTION OF ROOFED SLURRY STORAGE AND ASSOCIATED
WORKS**

**LLEOLIAD / LOCATION: LLWYDIARTH, LLWYDIARTH ROAD, PONTFADOG,
WREXHAM, LLANGOLLEN, LL20 7AG**

Thank you for consulting Cyfoeth Naturiol Cymru / Natural Resources Wales about the above, which we received on 19th August 2021.

We have no objection to the proposed development as submitted and provide the following advice.

Protected Sites and Foul Drainage

We note the application site is within the catchment of the River Dee and Bala Lake Special Area of Conservation (SAC). As you are aware, on the 21st January 2021, we published an evidence package outlining phosphorus levels for all river SACs across Wales. As part of this package, we issued a [Planning Position Statement](#), in which we advised that any proposed development that might increase the amount of phosphate (or phosphorus) within a river SAC catchment could lead to damaging effects to the SAC. Therefore, such proposals should be screened through a Habitats Regulations Assessment (HRA), to determine whether they are likely to have a significant effect on the SAC.

We note from the information submitted that a new covered slurry lagoon is to be installed to comply with storage requirements as laid down in the Water Resources (Control of Agricultural Pollution) (Wales) Regulations 2021. The structure is not to accommodate an increase in stock number.

Provided the structure is designed and built by a suitably qualified engineer to meet the standards set in the Regulations and BS 5502 (Building and Structures for Agriculture Code of Practice for Design, Construction and Loading), it is unlikely to increase the amount of

phosphorus entering the catchment and therefore, it is not likely to have a significant effect on the River Dee and Bala Lake SAC.

We refer you to our [Planning Advice](#) (May 2021). Provided this guidance is followed and you are able to conclude that the development is not likely to have a significant effect on the SAC, we have no objection to the proposal. However, should you conclude that the proposed development is likely to have a significant effect on the SAC, please consult us on your Appropriate Assessment under Regulation 63 of the Conservation of Habitats and Species Regulations 2017 (as amended).

Protected Sites

Site of Special Scientific Interest (SSSI)

We have considered the information submitted in support of the above application. Based on the information submitted, we consider that the proposed development is not likely to damage the features for which River Dee SSSI is of special interest.

Pollution Prevention

We understand this proposal is not to in relation to an increase in stock number.

Provided the structure is designed and built by a suitably qualified engineer to meet the standards set in the Regulations and BS 5502 (Building and Structures for Agriculture Code of Practice for Design, Construction and Loading), we have no water quality concerns. See Advice to Developer below for further advice.

Other Matters

Our comments above only relate specifically to matters included on our checklist, *Development Planning Advisory Service: Consultation Topics* (September 2018), which is published on our [website](#). We have not considered potential effects on other matters and do not rule out the potential for the proposed development to affect other interests.

We advise the applicant that, in addition to planning permission, it is their responsibility to ensure they secure all other permits/consents/licences relevant to their development. Please refer to our [website](#) for further details.

Advice for the Developer

Environmental Management

All works at the site must be carried out in accordance with PPG6: 'Working at construction and demolition sites' which are available on the following website:

<http://www.netregs.org.uk/environmental-topics/pollution-prevention-guidelines-ppgs-and-replacement-series/guidance-for-pollution-prevention-gpps-full-list/>

The activity of importing waste into the site for use as, for example hardcore, must be registered with Natural Resources Wales as an exempt/permittable activity under the Environmental Permitting Regulations 2016. The developer should contact Natural Resources Wales to discuss the necessity for an exemption/permit for any material imported to and exported from the site.

If during construction/excavation works any contaminated material is revealed, then the movement of such material either on or off site should be done in consultation with Natural Resources Wales. Any waste excavation material or building waste generated in the course of the development must be disposed of satisfactorily and in accordance with Section 34 of the Environmental Protection Act 1990. Carriers transporting waste from the site must be registered waste carriers and movement of any Hazardous Waste from the site must be accompanied by Hazardous waste consignment notes.

Agriculture

The facilities must comply with the Water Resources (Control of Pollution) (Silage and Slurry) (Wales) Regulations 2010. Site operators should ensure that there is no possibility of contaminated water entering and polluting surface or groundwater.

Please refer to the link below for further information:

<http://naturalresources.wales/guidance-and-advice/business-sectors/farming/good-farming-practice/?lang=en>

If you have any queries on the above, please do not hesitate to contact us.

Yn gywir / Yours faithfully

Rachael Burke

Cynghorydd - Cynllunio Datblygu / Advisor - Development Planning
Cyfoeth Naturiol Cymru / Natural Resources Wales