

Wrexham County Borough Council
16, Lord Street
Wrexham
LL11 1LG

Date: 01/12/2021
Our Ref: PLA0061498
Your Ref: P/2021/1081

Dear Sir/Madam,

Site: Wrexham Mill, Bridge Road, North Wrexham.
Development: Discharge Of Condition 6 (Drainage) Of Planning Permission P/2020/0599

We refer to the above application regarding the information submitted pursuant to the discharge of condition no. 6 attached to the above planning permission

We have reviewed drawing reference Drainage Layout which shows the proposed foul and surface water drainage, with foul water discharging to public sewer and surface water discharging to public sewer at an attenuated discharge rate of 5 l/s and comment as follows:

Welsh Water has no objection to discharge of condition no.6 attached to above planning consent.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at developer.services@dwrcymru.com

Please quote our reference number in all communications and correspondence.

Yours faithfully,

Rhodri Perry
Development Control Officer
Developer Services