

Wrexham County Borough Council
16, Lord Street
Wrexham
LL11 1LG

Date: 20/10/2021
Our Ref: PLA0060494
Your Ref: P/2021/0925

Dear Sir/Madam,

Site: 3 Flat 1, Wrexham.

Development: Change of use of first floor office to 1 apartment.

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

Welsh Water has no objection to change of use from first floor office to one apartment.

SEWERAGE

The proposed development site is crossed by a public sewer, please see copy of indicative public sewer record attached. No operational development is to take place within 3 metres either side of the centreline of the sewer. We request that prior to commencing any operational development the location of this asset is determined. If operational development is to take place within 3 metres either side of the centreline of the sewer please stop works and contact us. Under Water Industry Act 1991 Welsh Water has rights of access to its assets at all times.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at developer.services@dwrcymru.com

Please quote our reference number in all communications and correspondence.

Yours faithfully,

Rhodri Perry
Development Control Officer
Developer Services



We welcome correspondence in
Welsh and English

Dŵr Cymru Cyf, a limited company registered in
Wales no 2366777. Registered office: Pentwyn Road,
Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y
Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng
Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn
Nelson, Treharris, Morgannwg Ganol CF46 6LY.