

Maes Y Ffynnon,
Penrhosgarnedd,
Bangor,
Gwynedd
LL572DW

Wrexham County Borough Council,
The Guildhall,
Wrexham,
LL11 1AY

ebost/email:
northplanning@cyfoethnaturiolcymru.gov.uk

15/11/2021

Annwyl Syr/Madam / Dear Sir/Madam,

BWRIAD / PROPOSAL: CAIS AMLINELLLOL AR GYFER CODI ANNEDD (CADW POB MATER) / OUTLINE APPLICATION FOR ERECTION OF DWELLING (ALL MATTERS RESERVED)

LLEOLIAD / LOCATION: LAND AT HOLLYCROFT, BRYN ESTYN ROAD, WREXHAM, LL13 9TY

Thank you for consulting Cyfoeth Naturiol Cymru / Natural Resources Wales about the above, which we received on 27/10/2021

We have concerns with the application as submitted because inadequate information has been provided in support of the proposal. To overcome these concerns, you should seek further information from the applicant regarding protected sites and foul drainage. If this information is not provided, we would object to this planning application. Further details are provided below.

We also advise that based on the information submitted to date, a condition regarding protected species should be attached to any planning permission granted. Without the inclusion of this condition we would object to this planning application.

Protected Sites and Foul Drainage

We note the application site is within the catchment of the River Dee and Bala Lake Special Area of Conservation (SAC). As you are aware, on the 21st January 2021, we published an evidence package outlining phosphorus levels for all river SACs across Wales. As part of this package, we issued a [Planning Position Statement](#), in which we advised that any proposed development that might increase the amount of phosphate (or phosphorus) within a river SAC catchment could lead to damaging effects to the SAC. Therefore, such proposals should be screened through a Habitats Regulations Assessment (HRA), to determine whether they are likely to have a significant effect on the SAC. We have also

issued [Planning Advice](#) (May 2021) which gives specific advice in respect of foul drainage arrangements for new developments.

We note from the information submitted that the development has the potential to increase the amount of phosphorus being discharged from the site. As such, we refer you to our [Planning Advice](#) and advise you to seek further information from the applicant as identified in the sections titled 'What does this mean for development proposals involving connection to public wastewater treatment works', or 'What does this mean for development proposals involving private sewage treatment systems' of that advice.

Provided this advice is followed and you are able to conclude that the development is not likely to have a significant effect on the SAC, we would have no objection to the proposal. However, should you conclude that the proposed development is likely to have a significant effect on the SAC, please consult us on your Appropriate Assessment under Regulation 63 of the Conservation of Habitats and Species Regulations 2017 (as amended).

Protected Species

Great Crested Newt (GCN)

We note that the ecological report submitted in support of the above application (Preliminary Ecological Appraisal Land adjacent to Holly Croft Cottage, Bryn Estyn Road, Wrexham, Tyrer Ecological Consultants, 8/10/2021) states in section 8.12 that an Amphibian Reasonable Avoidance Measures (RAMs) scheme is recommended.

GCN and their breeding and resting places are protected under the Conservation of Habitats and Species Regulations 2017 (as amended). We advise that any consent is subject to the imposition of the following condition in respect of GCN.

Provided this advice is compliantly implemented, we consider that the proposed development is not likely to be detrimental to the maintenance of the favourable conservation status of the local population of GCN present at this site.

Condition 1: No development shall commence until a GCN Method Statement has been submitted to and approved in writing by the Local Planning Authority. The Method Statement should include, but not necessarily be limited to:

- the submission of details and plans concerning GCN reasonable avoidance and mitigation measures including fence construction and maintenance;
- details of timing, phasing and duration of construction activities and conservation measures;
- a timetable for implementation demonstrating that works are aligned with the proposed phasing of the development; and,
- persons responsible for implementing the works.

The Method Statement shall be carried out in accordance with the approved details.

Justification: To ensure that an approved GCN Method Statement is implemented, which protects GCN affected by the development.

NRW would refer you to the Chief Planning Officer's letter dated 1 March 2018 which advises Local Planning Authorities to attach an informative regarding licence requirements to all consents and notices where European Protected Species are likely to be present on site.

Other Matters

Our comments above only relate specifically to matters included on our checklist, *Development Planning Advisory Service: Consultation Topics* (September 2018), which is published on our [website](#). We have not considered potential effects on other matters and do not rule out the potential for the proposed development to affect other interests.

We advise the applicant that, in addition to planning permission, it is their responsibility to ensure they secure all other permits/consents/licences relevant to their development. Please refer to our [website](#) for further details.

Advice for the Developer

Environmental Management

All works at the site must be carried out in accordance with PPG6: 'Working at construction and demolition sites' which are available on the following website:

<http://www.netregs.org.uk/environmental-topics/pollution-prevention-guidelines-ppgs-and-replacement-series/guidance-for-pollution-prevention-gpps-full-list/>

The activity of importing waste into the site for use as, for example hardcore, must be registered with Natural Resources Wales as an exempt/permittable activity under the Environmental Permitting Regulations 2016. The developer should contact Natural Resources Wales to discuss the necessity for an exemption/permit for any material imported to and exported from the site.

If during construction/excavation works any contaminated material is revealed, then the movement of such material either on or off site should be done in consultation with Natural Resources Wales. Any waste excavation material or building waste generated in the course of the development must be disposed of satisfactorily and in accordance with Section 34 of the Environmental Protection Act 1990. Carriers transporting waste from the site must be registered waste carriers and movement of any Hazardous Waste from the site must be accompanied by Hazardous waste consignment notes.

If you have any queries on the above, please do not hesitate to contact us.

Yn gywir / Yours faithfully,

Rhys Jones

Cynghorydd - Cynllunio Datblygu / Advisor - Development Planning

Cyfoeth Naturiol Cymru / Natural Resources Wales