

Maes Y Ffynnon,
Penrhosgarnedd,
Bangor,
Gwynedd
LL572DW

Wrexham County Borough Council,
The Guildhall,
Wrexham,
LL11 1AY

ebost/email:
northplanning@cyfoethnaturiolcymru.gov.uk

23/08/2021

Annwyl Syr/Madam / Dear Sir/Madam,

**BWRIAD / PROPOSAL: ADEILADU 21 ANNEDD TAIR A PHEDAIR YSTAFELL WELY
GYDA GWAITH
CYSYLLTIEDIG / ERECTION OF 21 THREE AND FOUR BEDROOM DWELLINGS
WITH ASSOCIATED WORKS**

**LLEOLIAD / LOCATION: FORMER AIR PRODUCTS SITE, LLANGOLLEN ROAD,
ACREFAIR, WREXHAM, LL14 3HW**

Thank you for consulting Cyfoeth Naturiol Cymru / Natural Resources Wales about the above, which we received on 17th August 2021.

We have concerns with the application as submitted because inadequate information has been provided in support of the proposal. To overcome these concerns, you should seek further information from the applicant regarding foul drainage and protected species. If this information is not provided, we would object to this planning application. Further details are provided below.

Foul Drainage and Protected Sites

We note the application site is within the catchment of the River Dee and Bala Lake Special Area of Conservation (SAC). As you are aware, on the 21st January 2021, we published an evidence package outlining phosphorus levels for all river SACs across Wales. As part of this package, we issued a [Planning Position Statement](#), in which we advised that any proposed development that might increase the amount of phosphate (or phosphorus) within a river SAC catchment could lead to damaging effects to the SAC. Therefore, such proposals should be screened through a Habitats Regulations Assessment (HRA), to determine whether they are likely to have a significant effect on the SAC. We have also issued [Planning Advice](#) (May 2021) which gives specific advice in respect of foul drainage arrangements for new developments.

We note from the information submitted that the development has the potential to increase the amount of phosphorus being discharged from the site. As such, we refer you to our [Planning Advice](#) and advise you to seek further information from the applicant. We note that information has already been submitted in respect of confirming that foul drainage will be connected to the mains sewer. However, we advise you to seek further information as identified in the bullet point list given in the section titled 'What does this mean for development proposals involving connection to public wastewater treatment works' of that advice.

Provided this advice is followed and you are able to conclude that the development is not likely to have a significant effect on the SAC, we would have no objection to the proposal. However, should you conclude that the proposed development is likely to have a significant effect on the SAC, please consult us on your Appropriate Assessment under Regulation 63 of the Conservation of Habitats and Species Regulations 2017 (as amended).

Protected Species

We note that the Ecology Briefing Note (Kingdom Ecology, May 2021) proposes further survey work to be carried out before the submission of a planning application to the Local Authority however no further ecological information appears to have been presented. We advise that the Ecology Briefing Note has insufficient information to assess the need for avoidance / mitigation measures.

Risk to Controlled Waters

We have considered the information presented in the Coal Mining Report (Earth Environmental & Geotechnical, December 2019; Coal Mining Risk Assessment) submitted in support of this application. We assume that this report is in relation to the investigation to the underlying geology and coal workings, and isn't related to risks to water, noting there is no reference to contaminated land or groundwater within the report. On this basis, we have no further comments to add at this stage.

Should further works involve contaminated land and Controlled Waters risk, we would ask to be further advised.

Other Matters

Our comments above only relate specifically to matters included on our checklist, *Development Planning Advisory Service: Consultation Topics* (September 2018), which is published on our [website](#). We have not considered potential effects on other matters and do not rule out the potential for the proposed development to affect other interests.

We advise the applicant that, in addition to planning permission, it is their responsibility to ensure they secure all other permits/consents/licences relevant to their development. Please refer to our [website](#) for further details.

Advice for the Developer

Pollution Prevention

During the construction phase you should take any precaution to prevent contamination of surface water drains and local watercourses. Oils and chemicals should be stored in bunded areas and spill kits should be readily available in case of accidental spillages.

For further guidance please refer to GPP 5 and PPG 6 at the following link:

<http://www.netregs.org.uk/environmental-topics/pollution-prevention-guidelines-ppgs-and-replacement-series/guidance-for-pollution-prevention-gpps-full-list/>

Environmental Management

All works at the site must be carried out in accordance with PPG6: 'Working at construction and demolition sites' which are available on the following website:

<http://www.netregs.org.uk/environmental-topics/pollution-prevention-guidelines-ppgs-and-replacement-series/guidance-for-pollution-prevention-gpps-full-list/>

The activity of importing waste into the site for use as, for example hardcore, must be registered with Natural Resources Wales as an exempt/permittable activity under the Environmental Permitting Regulations 2016. The developer should contact Natural Resources Wales to discuss the necessity for an exemption/permit for any material imported to and exported from the site.

If during construction/excavation works any contaminated material is revealed, then the movement of such material either on or off site should be done in consultation with Natural Resources Wales. Any waste excavation material or building waste generated in the course of the development must be disposed of satisfactorily and in accordance with Section 34 of the Environmental Protection Act 1990. Carriers transporting waste from the site must be registered waste carriers and movement of any Hazardous Waste from the site must be accompanied by Hazardous waste consignment notes.

Waste produced during construction

Waste produced during the construction phase of your development must be dealt with appropriately and be in line with all relevant waste legislation including Duty of Care Regulations and Hazardous Waste Regulations. As part of your waste duty of care you must classify the waste produced:

- before it is collected, disposed of or recovered
- to identify the controls that apply to the movement of the waste
- to complete waste documents and records
- to identify suitably authorised waste management options
- to prevent harm to people and the environment.

Any waste removed from site will be subject to waste management controls. The links below provide information on how to classify waste and register as a waste carrier or hazardous waste producer:

<https://naturalresources.wales/permits-and-permissions/waste/?lang=en>

<https://naturalresources.wales/permits-and-permissions/waste/waste-permits/?lang=en>

Further guidance can be found on the GOV website here:

<https://www.gov.uk/managing-your-waste-an-overview/duty-of-care>

Landfill

According to our records the proposed development site is located near to land that is, or has been, used for the deposition of waste material. We would therefore advise you to consult with the local authority's Environmental Health and Building Control Departments, as they may hold detailed records, and may wish to make appropriate recommendations in respect of landfill gas investigation/remedial work. The developers should be made aware of the existence of the landfill site(s) so that they can decide whether or not to make their own investigations into the presence of landfill gas. It should also be noted that Waste Management Paper 27 states "It has been found that many sites which have taken only supposedly 'inert' waste have produced gas".

If you have any queries on the above, please do not hesitate to contact us.

Yn gywir / Yours faithfully

Rachael Burke

Cynghorydd - Cynllunio Datblygu / Advisor - Development Planning
Cyfoeth Naturiol Cymru / Natural Resources Wales