

P/2021/0884 Wrexham Recycling centre, Redwither Road, Wrexham Industrial estate LL13
9RD PLA0060002 8/10/2021

Hi Simon,

In relation to below queries please see our response

- A) We can accommodate flows from the proposed development, this discharges to Five Fords waste water treatment works which does have a phosphate consent. The acceptance of flows will still be within our phosphate consent.
- B) The necessary treatment capacity is existing at the treatment works, there are no plan for reinforcement works at this works within this AMP.

Should you require anything further please let me know.

Thank you,

Rhodri



Rhodri Perry

Development Control Officer | Developer Services
Dŵr Cymru Welsh Water



W: dwrcymru.com



E: developer.services@dwrcymru.com



T: 0800 917 2652 | M: 07557 849514



A: PO Box 3146, Cardiff, CF30 0EH



Before you print please think about the **ENVIRONMENT**

If we've gone the extra mile to provide you with excellent service, let us know. You can nominate an individual or team for a Diolch award through our [website](#)