

Wrexham County Borough Council
16, Lord Street
Wrexham
LL11 1LG

Date: 04/10/2021
Our Ref: PLA0060049
Your Ref: P/2021/0891

Dear Sir,

Site: Parkview Garage, Ruthin Road, Wrexham.
Development: Erection of Fence

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

Welsh Water have no objection to proposed fence

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at developer.services@dwrcymru.com

Please quote our reference number in all communications and correspondence.

Yours faithfully,

Rhodri Perry
Development Control Officer
Developer Services