

Cerys Jones

From: North Planning <NorthPlanning@cyfoethnaturiolcymru.gov.uk>
Sent: 06 September 2021 15:08
To: Bryn Bolton; Cerys Jones
Subject: P/2021/0055 - Land adjacent to Bronydd High Street, Glyn Ceiriog, Wrexham (Minor) V3 - NRW Response NRW:07141512
Attachments: P-2021-0055 Response CAS-164354-G1C6.pdf

Dear Bryn and Cerys,

Please find attached our response to the above application, if you have any queries please do not hesitate to contact me.

The Applicant should be aware that should a connection to the mains sewer not be feasible, they will also need to demonstrate that the proposal would not pose an unacceptable risk to the water environment. Welsh Government Circular 008/2018 advises that a full and detailed consideration be given to the environmental criteria listed under paragraph 2.6 of the Circular, in order to justify the use of private sewerage.

The Applicant should also be aware that should a connection to the mains sewer not be feasible, they will need to apply for an environmental permit or register an exemption with us. As stated above, we expect developers discharging domestic sewage to connect to the public foul sewer where it is reasonable to do so. We will not normally grant a discharge permit for a private sewage treatment system where it is reasonable to connect to the public foul sewer. We also expect discharges of trade effluent to connect to the public foul sewer where it is reasonable to do so and subject to the sewerage undertaker granting a trade effluent consent or entering into a trade effluent agreement.

Septic tanks and small sewage treatment works may be registered as exempt from the requirement to obtain an environmental permit if certain criteria are met. Please note, should a permit be required, further information may be required as part of that application and the Applicant is therefore advised to hold pre-application discussions with our Permitting Team on 0300 065 3000, at the earliest opportunity, to try to ensure that there is no conflict between any planning permission granted and the permit requirements. It is important to note that a grant of planning permission does not guarantee that a permit will be granted, should a proposal be deemed to be unacceptable (either because of environmental risk or because upon further investigation, a connection to mains sewer was feasible). The Applicant should ensure that they have all the required permissions, consents, permits and any other approvals in place prior to commencement of works on the site.

More information, including a step by step guide to registering and the relevant application forms are available on our [website](#). Where private sewage treatment/disposal facilities are utilised, they must be installed and maintained in accordance with British Standard 6297 and Approved Document H of the Building Regulations. We also refer the Applicant to Guidance for Pollution Prevention 4 on the [NetRegs website](#), which provides further information.

Please note, a lack of capacity, or plans to improve capacity in the sewer, is not a valid reason for a sewerage undertaker to refuse connection under Section 106 of the Water Industry Act 1991 and we may refuse to issue an environmental permit or exemption for private treatment facilities in such circumstances.

Kind regards,

Tristan Williams

Tîm Cynllunio Datblygu / Development Planning Team
Cyfoeth Naturiol Cymru / Natural Resources Wales

www.cyfoethnaturiolcymru.gov.uk / www.naturalresourceswales.gov.uk

Yn falch o arwain y ffordd at ddyfodol gwell i Gymru trwy reoli'r amgylchedd ac adnoddau naturiol yn gynaliadwy / Proud to be leading the way to a better future for Wales by managing the environment and natural resources sustainably.

Croesewir gohebiaeth yn Gymraeg a byddwn yn ymateb yn Gymraeg, heb i hynny arwain at oedi / Correspondence in Welsh is welcomed, and we will respond in Welsh without it leading to a delay.