

MEMORANDUM

From: Ian Jones Public Protection
Service Manager

To: David Williams Planning
Control Manager

Our Ref:

Your Ref: P/2018 /0874

Date: 01-11-2018

Town and Country Planning Act 1990

Town and Country Planning (General Development Procedure) Order 1996

Re: P/2018 /0874, SITE OF FORMER HIPPODROME THEATRE HENBLAS STREET WREXHAM

FULL PLANNING APPLICATION FOR THE ERECTION OF MIXED USE DEVELOPMENT COMPRISING 10 NO. STUDIO APARTMENTS AND 3 NO. 1 BEDROOM APARTMENTS AT FIRST AND SECOND FLOORS OVER 2 NO. RETAIL UNITS AT GROUND FLOOR

Environmental Protection

For the operational phase of the commercial units it may be necessary to restrict times of deliveries in order to protect the amenity of nearby sensitive receptors (including the future occupants of the apartments)

ZP04 - AIR HANDLING / EXTRACTION PLANT BS4142 ASSESSMENT

For the operational phase of the commercial units:

The rating level of any noise generated by air handling plant associated with the development shall not exceed the pre-existing background level by more than 5dB(A) at any time. The noise levels shall be determined at nearby noise sensitive premises, and measurements and assessment shall be made in accordance with BS4142:2014 Methods for rating and assessing industrial and commercial sound.

ZP06 - PROTECTION OF AMENITY FROM NUISANCE

All works in relation to the implementation of this permission, including deliveries to and/or leaving the site, shall be undertaken only between the hours of 07.30 to 18.00 Monday to Friday, 08.00 to 14.00 on a Saturday, and at no time on a Sunday or a Bank Holiday.

ZP07 - TAN11 NOISE SURVEY REQUIRED (TO BE SUBMITTED)

To protect the amenity of the apartments" future occupants:

No part of the development shall commence until a noise survey in order to determine noise levels for both day and night has been carried out, and a detailed report of the survey findings together with a detailed scheme of noise attenuation and or noise insulation measures has been submitted to and approved in writing by the Local Planning Authority. The measures as are approved shall be fully implemented prior to the first occupation / use of the development.

ZP11 - DUST MANAGEMENT SCHEME REQUIRED BY CONDITION

No part of the development shall commence until an appropriate Dust Management Scheme has been submitted to and approved in writing by the Local Planning Authority. The dust mitigation measures as are approved shall be fully implemented for the entire duration of the construction phase.

A21N - EPA 1990 NOISE NUISANCE ADVICE

The applicant is advised that compliance with condition no. @@ does not provide an exemption from the statutory noise nuisance provisions of the Environmental Protection Act 1990. Any complaints received relating to noise from the development during the permitted hours may still be investigated using the Council's Standardised Procedure for Dealing with Noise Nuisance Complaints and legal action may be taken where appropriate.

A22N - Construction Noise

The applicant is advised that the Council has the option to control construction noise by serving a Control of Pollution Act 1974, Section 60, Notice where deemed necessary. Failure to comply with such a Notice can result in prosecution. For further information and advice regarding construction noise please contact the Council's Environment and Planning Department on 01978 292040.

A23N - BURNING OF WASTE ADVICE

Burning of waste generated from construction activities is not considered to be an appropriate method of disposal and action may be taken as follows:

- Under the Environmental Protection Act 1990 anyone found disposing of construction site waste by burning is likely to be in breach of their duty of care with regard to waste disposal;
- Under the same Act an abatement notice may be served where smoke is judged to be causing a nuisance to neighbouring properties. Failure to comply with the requirements of such a notice can result in prosecution;
- Under the Clean Air Act 1993 it is an offence for a commercial activity to burn anything that gives rise to dark smoke.

To prevent offences under the above named Acts there should be no bonfires on the site, to include the prohibition of the burning of cleared vegetation. The applicant should contact the Council's Environment and Planning Department on 01978 292040 for further advice and information.

A24N - DUST MANAGEMENT SCHEME (SCHEME REQUIRED BY CONDITION)

Applicants are advised that compliance with condition no. @@ does not provide an exemption from the statutory nuisance provisions of the Environmental Protection Act 1990. Under the Act dust from any type of activity can be judged to be causing a statutory nuisance to neighbouring properties. A legal notice can be served requiring that the dust nuisance is abated and failure to comply with the requirements of the notice can result in prosecution. The applicant should contact the Council's Environment and Planning Department on 01978 292040 for further advice and information.

A26N - TAN11 NOISE SURVEY ADVICE

The development site is in close proximity to commercial noise sources. The developer is therefore required to carry out a noise survey in connection with condition no. @@ in order to determine noise levels for both day (07.00 – 23.00 hours) and night (23.00 – 07.00 hours) having regard to Planning Guidance (Wales), Technical Advice Note (TAN) 11 – Noise. The report of the noise survey findings shall include:

- a) Noise levels arising from day/night time activities in the vicinity of the proposed development site and the impact upon the proposed accommodation, and
- b) A detailed scheme of noise insulation and / or attenuation measures so designed to safeguard the amenity of the

future occupants of the proposed accommodation hereby approved.

Contaminated Land

No Comments

.....

Head of Planning and Environment