

Susan Davies

From: Sharon Holman
Sent: 05 September 2018 09:59
To: planning_admin
Subject: FW: P/2018/0625 - Saron Chapel

Civ – flood officer resp

From: Neil Taunt
Sent: 05 September 2018 08:32
To: Cathy Owen
Cc: David Hughes; Sharon Holman
Subject: RE: P/2018/0625 - Saron Chapel

Hi Cathy,

Yes, some form of assessment is required that considers the risks that I have highlighted in my consultation response to the planning application. As detailed in that response, *"the site is bounded by a small un named watercourse and would appear to be located within a topographical low point. NRW's updated flood map for surface water does identify a risk of surface water flooding to the site, and we hold a number of reports of surface water and rapid flash flooding in the immediate vicinity of the site. As the application is for a change of use to a higher vulnerability use, with reported incidents of flooding in the immediate vicinity of the site I would strongly recommend a flood consequence assessment is submitted in support of the application to better define the risks to the site from fluvial flooding, blockage of local drainage infrastructure and surface water runoff and propose mitigation to minimise the impact of any future flooding to the development and surroundings."*

This assessment should be used to better define the risks to the site from the local flood risk sources referenced above as well as identify any suitable mitigation that could be incorporated into the proposed development to ensure any identified flood risk can be acceptably managed into the future. It is worth noting that NRW and the TAN15 Development Advice Maps do not explicitly consider the sources of risk identified.

More than happy to discuss further if required.

Many thanks

Neil

Neil Taunt MCIWEM C.WEM CEnv CSci
Uwch Swyddog Rheoli Llifogydd / Senior Flood Management Officer



☎ 01978 729734 / 07808 787632
✉ Amgylchedd a Chynllunio, Cyngor Bwrdeistref Sirol Wrecsam, De Ffordd yr Abaty, Ystad Ddiwydiannol Wrecsam, Wrecsam LL13 9PW
✉ Environment & Planning, Wrexham County Borough Council, Abbey Road South, Wrexham Industrial Estate, Wrexham LL13 9PW
🌐 wrecsam.gov.uk | wrexham.gov.uk
🐦 twitter.com/cbswrecsam | twitter.com/wrexhamcbc
📘 facebook.com/cyngorwrecsam | facebook.com/wrexhamcouncil

From: Cathy Owen [<mailto:cathyowen@lawray.co.uk>]
Sent: 04 September 2018 10:59
To: Neil Taunt
Cc: David Hughes
Subject: P/2018/0625 - Saron Chapel

Hi Neil

I trust you are well. We are currently trying to resolve the issues regarding flood risk to Saron Chapel.

Can you confirm if the Flood Consequence Assessment is still required for this current application?

Kind Regards,

Cathy Owen
Architectural Technician

T: 01978 357 887
M: 07772 113 971
W: www.lawray.co.uk



This e-mail is confidential and may contain legally privileged information; it is intended for the use of the addressee only. If you are not the addressee you must not read, use, distribute copy or rely on this e-mail. If you have received this communication in error please notify us immediately by e-mail or by telephone. lawray believes that this e-mail and any attachments are free of viruses. However, it is the responsibility of the recipient to ensure it is virus free. lawray does not accept any responsibility for any loss or damage that may arise from the use of this e-mail or its contents.

Lawray Limited Registered Office 1 Cae Gwyrdd, Greenmeadow Springs, CARDIFF CF15 7AB Reg. Co. No. 2724178, VAT Reg. No. 134 2146 06