

## Cerys Jones

---

**From:** Sharon Holman  
**Sent:** 07 August 2018 10:59  
**To:** planning\_admin  
**Subject:** FW: P/2018/0608 - Big Green farm Penley

Civ - flood officer response

---

**From:** Carole Wright <[Carole.Wright@wrexham.gov.uk](mailto:Carole.Wright@wrexham.gov.uk)>  
**Sent:** 7 Aug 2018 10:51  
**To:** Sharon Holman <[Sharon.Holman@wrexham.gov.uk](mailto:Sharon.Holman@wrexham.gov.uk)>  
**Subject:** P/2018/0608 - Big Green farm Penley

Hi there

In Neil's absence I have had a look at the reserved matters submission. The FCA does not contain any calculations to support the proposal of soakaways, it only states that this is the best method!!

The developer need to provide percolation test result to support their proposal as indicated on the attached guidance note.

If you require any more detailed info, you will have to wait for Neil to return..

thanks

*Carole Wright*

**Carole Wright - BA MBCS**

Technical Flood Support Officer - Swyddog Technegol Cefnogi Llifogydd



01978 729735



Wrexham County Borough Council, Environment and Planning Department Abbey Road South Wrexham Industrial Estate Wrexham LL13 9PW



Cyngor Bwrdeistref Sirol Wreccsam, Amgylchedd a Chynllunio De Ffordd yr Abaty Ystâd Ddiwydiannol Wreccsam Wreccsam LL13 9PW



[wrexham.gov.uk](http://wrexham.gov.uk) | [wreccsam.gov.uk](http://wreccsam.gov.uk)



[twitter.com/wrexhamcbc](https://twitter.com/wrexhamcbc) | [twitter.com/cbswreccsam](https://twitter.com/cbswreccsam)



[facebook.com/wrexhamcouncil](https://facebook.com/wrexhamcouncil) | [facebook.com/cyngorwreccsam](https://facebook.com/cyngorwreccsam)