

Cerys Jones

From: Sharon Holman
Sent: 23 July 2018 14:35
To: planning_admin
Subject: FW: P/2018/0557

Civ – flood officer resp

From: Neil Taunt
Sent: 23 July 2018 13:31
To: Sharon Holman
Subject: P/2018/0557

Hi Sharon,

Due to the scale and temporary nature of the proposal I have no objection in principle to the proposal, but this should not imply any future development of the site would be able to benefit from a connection initially into the highway drainage network as this is contrary to normal working practice. It is highly likely that the existing highway drain will discharge into the local public sewer network – as such Welsh Water are likely to have an opinion on this.

If you have any questions please let me know.

Many thanks

Neil

Neil Taunt MCIWEM C.WEM CEnv CSci

Uwch Swyddog Rheoli Llifogydd / Senior Flood Management Officer



☎ 01978 729734 / 07808 787632

✉ Amgylchedd a Chynllunio, Cyngor Bwrdeistref Sirol Wrexham, De Ffordd yr Abaty, Ystad Ddiwydiannol Wrexham, Wrexham LL13 9PW

✉ Environment & Planning, Wrexham County Borough Council, Abbey Road South, Wrexham Industrial Estate, Wrexham LL13 9PW

🌐 wrexham.gov.uk | wrexham.gov.uk

🐦 twitter.com/cbswrexham | twitter.com/wrexhamcbc

📘 facebook.com/cyngorwrexham | facebook.com/wrexhamcouncil