

Cerys Jones

From: Matthew Phillips
Sent: 20 November 2018 08:38
To: planning_admin
Subject: FW: Planning Application: P/2018/0898

Please add as general consultation response

From: Morgan Barbara [mailto:Barbara.Morgan@networkrail.co.uk]
Sent: 20 November 2018 08:36
To: Matthew Phillips
Subject: FW: Planning Application: P/2018/0898

Network Rail
1st Floor
Bristol Temple Point
Bristol
BS1 6NL

Ask for : Barbara Morgan
Tel : 0117 3721125

My Ref : P/TP18/0844/BM
Your Ref : P/2018/0898

Date : 20 November 2018

Dear Matthew Phillips

TOWN AND COUNTRY PLANNING ACT 1990

PROPOSAL: Erection of affordable housing units comprising 1 detached dwelling, 18 semi-detached dwellings and 6 flats and associated works.

Land off Jacques Way Wrexham

Thank you for your email dated 30 October, together with the opportunity to comment on this proposal.

Whilst there is no objection in principle to this proposal, Network Rail have Road/Rail access point renewal works planned at WSJ2 201m 57c which will be carried out within the next 3-5 years. The proposed development must not obstruct our access to carry out these works or our ability to access the railway at any time during or after construction.

The proposed retaining wall detailed design should be forwarded to the Network Rail's Asset Protection team prior to works taking place.

Notwithstanding the above, I give below my comments and requirements for the safe operation of the railway and the protection of Network Rail's adjoining land.

FOUNDATIONS

Network Rail offers no right of support to the development. Where foundation works penetrate Network Rail's support zone or ground displacement techniques are used the works will require specific approval and careful monitoring by Network Rail. There should be no additional loading placed on the cutting and no deep continuous excavations parallel to the boundary without prior approval.

DRAINAGE

All surface water drainage should be directed away from Network Rail's land to the public mains system. Soakaways are not acceptable where the following apply:

- Where excavations which could undermine Network Rail's structural support zone or adversely affect the bearing capacity of the ground
- Where there is any risk of accidents or other acts leading to potential pollution of Network Rail's property/infrastructure
- Where the works could adversely affect the water table in the vicinity of Network Rail's structures or earthworks.

GROUND DISTURBANCE

The works involve disturbing the ground on or adjacent to Network Rail's land it is likely/possible that the Network Rail and the utility companies have buried services in the area in which there is a need to excavate. Network Rail's ground disturbance regulations applies. The developer should seek specific advice from Network Rail on any significant raising or lowering of the levels of the site.

FENCING

If not already in place, the Developer/applicant must provide at their expense a suitable trespass proof fence (of at least 1.8m in height) adjacent to Network Rail's boundary and make provision for its future maintenance and renewal without encroachment upon Network Rail land. Network Rail's existing fencing / wall must not be removed or damaged and at no point either during construction or after works are completed on site should the foundations of the fencing or wall or any embankment therein be damaged, undermined or compromised in any way. Any vegetation on Network Rail land and within Network Rail's boundary must also not be disturbed.

SITE LAYOUT

It is recommended that all buildings be situated at least 2 metres from the boundary fence, to allow construction and any future maintenance work to be carried out without involving entry onto Network Rail's infrastructure. Where trees exist on Network Rail land the design of foundations close to the boundary must take into account the effects of root penetration in accordance with the Building Research Establishment's guidelines.

PILING

Where vibro-compaction/displacement piling plant is to be used in development, details of the use of such machinery and a method statement should be submitted for the approval of Network Rail's Asset Protection Engineer prior to the commencement of works and the works shall only be carried out in accordance with the approved method statement.

EXCAVATIONS/EARTHWORKS

All excavations / earthworks carried out in the vicinity of Network Rail's property / structures must be designed and executed such that no interference with the integrity of that property / structure can occur. If temporary compounds are to be located adjacent to the operational railway, these should be included in a method statement for approval by Network Rail. Prior to commencement of works, full details of excavations and earthworks to be carried out near the railway undertaker's boundary fence should be submitted for approval of the Local Planning Authority acting in consultation with the railway undertaker and the works shall only be carried out in accordance with the approved details. Where development may affect the railway, consultation with the Asset Protection Engineer should be undertaken.

SIGNALLING

The proposal must not interfere with or obscure any signals that may be in the area.

NOISE

Network Rail would remind the council and the applicant of the potential for any noise/ vibration impacts caused by the proximity between the proposed development and the existing railway, which must be assessed in the context of the National Planning Policy Framework (NPPF) and the local planning authority should use conditions as necessary. The current level of railway usage may be subject to change at any time without prior notification including increased frequency of trains, night time train running and heavy freight trains.

There is also the potential for maintenance works to be carried out on trains, which is undertaken at night and means leaving the trains' motors running which can lead to increased levels of noise.

We therefore strongly recommend that all future residents are informed of the noise and vibration emanating from the railway, and of potential future increases in railway noise and vibration.

LANDSCAPING

It is recommended no trees are planted closer than 1.5 times their mature height to the boundary fence. The developer should adhere to Network Rail's advice guide on acceptable tree/plant species. Any tree felling works where there is a risk of the trees or branches falling across the boundary fence will require railway supervision.

PLANT, SCAFFOLDING AND CRANES

Any scaffold which is to be constructed adjacent to the railway must be erected in such a manner that, at no time will any poles or cranes over-sail or fall onto the railway. All plant and scaffolding must be positioned, that in the event of failure, it will not fall on to Network Rail land.

LIGHTING

Any lighting associated with the development (including vehicle lights) must not interfere with the sighting of signalling apparatus and/or train drivers vision on approaching trains. The location and colour of lights must not give rise to the potential for confusion with the signalling arrangements on the railway.

SAFETY BARRIER

Where new roads, turning spaces or parking areas are to be situated adjacent to the railway; which is at or below the level of the development, suitable crash barriers or high kerbs should be provided to prevent vehicles accidentally driving or rolling onto the railway or damaging the lineside fencing.

ACCESS POINTS

Where Network Rail has defined access points, these must be maintained to Network Rail's satisfaction.

In order to mitigate the risks detailed above, the Developer should contact the Network Rail's Asset Protection Wales Team well in advance of mobilising on site or commencing any works. The initial point of contact is assetprotectionwales@networkrail.co.uk. The department will provide all necessary Engineering support subject to a Basic Asset Protection Agreement.

Please feel free to get in contact if you have any questions.

Yours sincerely,

Barbara Morgan
Town Planning Technician (Western & Wales)

www.networkrail.co.uk/property

Please send all Notifications and Consultations to townplanningwestern@networkrail.co.uk or by post to Network Rail, Town Planning, 1st Floor, Bristol Temple Point, Redcliffe Way, Bristol BS1 6NL

The content of this email (and any attachment) is confidential. It may also be legally privileged or otherwise protected from disclosure.

This email should not be used by anyone who is not an original intended recipient, nor may it be copied or disclosed to anyone who is not an original intended recipient.

If you have received this email by mistake please notify us by emailing the sender, and then delete the email and any copies from your system.

Liability cannot be accepted for statements made which are clearly the sender's own and not made on behalf of Network Rail.

Network Rail Infrastructure Limited registered in England and Wales No. 2904587, registered office
Network Rail, 2nd Floor, One Eversholt Street, London, NW1 2DN

