

25/10/2018

For the attention of Mared Rees:

Dear Mared,

TOWN AND COUNTRY PLANNING ACT 1990
DEDDF CYNLLUNIO GWLAD A THREF 1990

PROPOSAL:
Oak Farm, New Hall Lane, Bronington, Witchurch
LOCATION:
CONVERSION OF REDUNDANT FARM BUILDING TO DWELLING

Thank you for consulting Natural Resources Wales (NRW) about the above, which was received on 08/10/2018.

NRW does not object to the proposal, however we would provide the following advice.

Protected Species

We note that the Ecological Appraisal and Impact Assessment submitted in support of the above application. From the information submitted, we consider that the proposed development represents a lower risk for bats, as defined in our guidance document 'Natural Resources Wales Approach to Bats and Planning (2015)'. We also consider that the proposed development represents a lower risk for Great Crested Newts (GCNs). Bats and GCNs and their breeding and resting places are protected under the Conservation of Habitats and Species Regulations 2017.

As this is a lower risk case for bats and GCNs, we consider that the development is not likely to be detrimental to the maintenance of the population of the species concerned at a favourable conservation status in its natural range.

Furthermore, we advise that the proposed development is not likely to harm or disturb the bats or GCNs or their breeding sites and resting places at this site, provided the avoidance measures described in the Ecological Appraisal and Impact Assessment are implemented.

The report must be included in the 'approved list of plans / documents' condition within the decision notice should consent for the project be granted.

Please consult us again if any further information shows that this is no longer a lower risk case.

Foul Drainage

With respect to the discharge of effluent to ground or surface water, the Applicant will need to apply for an environmental permit or register an exemption with us. The Applicant must obtain any necessary permit or exemption prior to commencement of work on site. Septic tanks and small sewage treatment works may be registered as exempt from the requirement to obtain an environmental permit if certain criteria is met. Please note, should a permit be required, further information may be required as part of that application and the Applicant is therefore advised to hold pre-application discussions with our Permitting Team on 0300 065 3000, at the earliest opportunity, to try to ensure that there is no conflict between any planning permission granted and the permit requirements. More information, including a step by step guide to registering and the relevant application forms are available on our website. Where private sewage treatment/disposal facilities are utilised, they must be installed and maintained in accordance with British Standards 6297 and Approved Document H of the Building Regulations. We also refer the Applicant to Pollution Prevention Guideline 4 which provides further information.

Waste

Waste produced during construction

Waste produced during the construction phase of your development must be dealt with appropriately, and be in line with all relevant waste legislation including Duty of Care Regulations and Hazardous Waste Regulations. As part of your waste duty of care you must classify the waste produced:

- before it is collected, disposed of or recovered
- to identify the controls that apply to the movement of the waste
- to complete waste documents and records
- to identify suitably authorised waste management options
- to prevent harm to people and the environment.

Any waste removed from site will be subject to waste management controls. The links below provided information on how to classify waste and register as a waste carrier or hazardous waste producer:

<http://naturalresources.wales/waste/how-to-classify-and-assess-waste/?lang=en>

<http://naturalresources.wales/apply-for-a-permit/waste/?lang=en>

Further guidance can be found on the GOV website here:

<https://www.gov.uk/managing-your-waste-an-overview/duty-of-care>

Pollution Prevention

Please refer to PPG6, working at construction and demolition sites:

<https://www.sepa.org.uk/media/60125/ppg-6-working-at-construction-and-demolition-sites.pdf>

Any work which is to take place should be done so with pollution prevention in mind. Pollution prevention advice and guidance can be found via this link:

<http://www.netregs.org.uk/environmental-topics/pollution-prevention-guidelines-ppgs-and-replacement-series/guidance-for-pollution-prevention-gpps-full-list/>

Please do not hesitate to contact us if you require further information or clarification on any of the above.

Our comments above only relate specifically to matters that are listed in our 'Consultation Topics' document (September 2018) which is published on our website: (<https://cdn.naturalresources.wales/media/686847/dpas-consultation-topics-august-2018-eng.pdf?mode=pad&rnd=131819256840000000>). We have not considered potential effects on other matters and do not rule out the potential for the proposed development to affect other interests, including environmental interests of local importance.

Yn gywir / Yours sincerely,

Daniel Davies

Daniel Davies

Cynghorydd Cynllunio Datblygu / Development Planning Advisor

Cyfoeth Naturiol Cymru / Natural Resources Wales